



FCC Week 2018, Amsterdam

Staging and design of the cryogenic system for FCC-ee and HE-LHC

Laurent Tavian, CERN, ATS-DO





Content




- FCC-ee conceptual design
 - Basic input from SRF
 - Cryogenic plant layout and architecture
 - Staging proposal from $Z \rightarrow W \rightarrow H \rightarrow t\bar{t} \text{bar}1 \rightarrow t\bar{t} \text{bar}2$
 - Electrical consumption and helium inventory
- HE-LHC conceptual design
 - Temperature levels, heat loads & installed cooling capacity
 - How to deal with existing LHC tunnel and existing cryogenics?
 - Electrical consumption and helium inventory
- Conclusion



FCC-ee: RF configuration for the different machines



	Machine									
	Z		W		H		ttbar1 (ttbar2)			
	per beam	booster	per beam	booster	per beam	booster	2 beams	booster	2 beams	booster
Frequency - Temperature	400 MHz - 4.5 K						800 MHz - 2 K			
# cell / cav	1	4	4		4		4		5	
# cavities	52	12	52	52	136	136	272	136	296 (372)	400 (480)
# CM	13	3	13	13	34	34	68	34	74 (93)	100 (120)
dynamic losses/cav [W]	14	11	210	26	202	29	210	30	66	10
stat losses/cav [W]	8		8		8		8		8	






FCC-ee: Heat loads per machine



Heat load			Machine				
			Z	W	H	ttbar1	ttbar2
4.5 K static	Main rings	[W]	832	832	2176	2176	2176
	Booster	[W]	96	416	1088	1088	1088
	Distribution	[W]	515	545	734	734	734
	Total	[W]	1443	1793	3998	3998	3998
2 K static	Main rings	[W]	0	0	0	2368	2976
	Booster	[W]	0	0	0	3200	3840
	Distribution	[W]	0	0	0	227	247
	Total	[W]	0	0	0	5795	7063
4.5 K dynamic	Main rings	[W]	1456	21840	54944	57120	57120
	Booster	[W]	132	1352	3944	4080	4080
	Total	[W]	1588	23192	58888	61200	61200
	2 K dynamic	Main rings	[W]	0	0	0	19536
Booster		[W]	0	0	0	4000	4800
Total		[W]	0	0	0	23536	29352
50-75 K static		Main rings	[W]	817	980	2564	4935
	Booster	[W]	94	490	1282	4486	5127
	Distribution	[W]	6341	6441	7071	10740	11130
	Total	[W]	7252	7911	10916	20161	21802
Grand total 50-75 K [kW] [kW]			7.3	7.9	11	20	22
Grand total 4.5 K [kW] [kW]			3.0	25	63	65	65
Grand total 2 K [kW] [kW]			0	0	0	29	36



Heat loads largely dominated by dynamic loads


(w/o operational margin)



FCC-ee: Cryogenic plant capacity and layout




		Machine				
		Z	W	H	ttbar1	ttbar2
Nb of cryoplants	[-]	2	2	2	4	4
operational margin factor	[-]	1.3	1.3	1.3	1.3	1.3
Total @ 50-75 K	[kW/plant]	4.7	5.1	7.1	6.6	7.1
Total @ 4.5 K	[kW/plant]	2.0	16	41	21	21
Total @ 2 K	[kW/plant]	0	0	0	10	12
Cryoplant size	[kWeq @ 4.5 K]	2.2	16	41	55	63





FCC-ee: cryogenic plant architecture









FCC-ee: Cryogenic architecture




- Cryoplant A (2 kW @ 4.5 K)
- Cryoplant B (41-63 kW @ 4.5 K)
- Cryoplant C (63 kW @ 4.5 K)

- 400 MHz - 4.5 K
- 800 MHz - 2 K






FCC-ee: Cryo-plant staging



Refrigeration need per Point: 2 16 41 55 63



Reminder: Staging scenario similar to LEP-LHC:

- started with two 6 kW plants
- then four 12-18 kW plants (LEP2 – LEP2+); upgraded with 2.4 kW @ 1.8 K units for LHC.
- then four additional 18 kW including 1.8 K units for LHC



FCC-ee: Electrical consumption and He inventory



Electrical consumption


Machine	Installed power				Nominal power			
	per plant [MW]	per site [MW]	Total [MW]	COP [W/W]	per plant [MW]	per site [MW]	Total [MW]	COP [W/W]
Z	0.51	0.51	1.0	230	0.44	0.44	0.89	261
W	9.5	9.5	19	230	5.3	5.3	11	320
H	9.5	9.5	19	230	8.3	8.3	17	261
ttbar1	14	29	58	230	12	23	46	274
ttbar2	14	29	58	230	13	25	50	261

Helium inventory


Machine	Z	W	H	ttbar1	ttbar2
Cryomodule [t]	1.2	1.6	4.1	11.0	12.6
Distribution [t]	7.9	7.9	7.9	8.9	8.9
Cryoplant [t]	1	1	2	4	4
Total [t]	10	10	14	24	26

HE-LHC : temperature -pressure level

- Use of FCC-hh cryo-magnet design and cooling principle:
→ T cold-mass @ 1.9 K and 1.3 bar
- Beam screens cooled between 40-60 K, which corresponds to the optimum exergetic efficiency. The reduced specific load (8 W/m per beam) allows to operate at 20 bar.



Forbidden by vacuum and/or by surface impedance





HE-LHC : heat load in steady-state and transient operation



		FCC-hh [W/m]		HE-LHC [W/m]	
		40-60 K	1.9 K	40-60 K	1.9 K
Static heat inleaks	CM supporting system	2.4	0.13	2.4	0.13
	Radiative insulation		0.13		0.13
	Thermal shield	3.1		3.1	
	Feedthrough & vac. barrier	0.2	0.1	0.2	0.1
	Beam screen		0.12		0.12
	Distribution	3.6	0.1	3	0.1
	Total static	9.3	0.58	8.7	0.58
Steady-state dynamic heat loads	Synchrotron radiation	57	0.08	8	0.08
	Image current	3.4		4.46	
	Resistive heating		0.3		0.3
	e-clouds			0.2	
	Beam-gas scattering		0.45		0.18
	Total dynamic	60	0.83	13	0.56
	Total	70	1.4	21.4	1.1

Sector capacity need				
T level	Steady-state	Transient	Total	
40-60 K	81		81	[kW]
1.9 K	3.3	1.1	4.4	[kW]
40-300 K	65		65	[g/s]
	Cryoplant size		25	[kWeq @ 4.5 K]

+ 1.1 kW at 1.9 K per sector to extract deposited energy (AC-losses) during ramp-up in less than 2 hours


(Including operational margins of 1.3 for 40-60 K and 40-300 K temperature level)



HE-LHC : Re-use of LHC cryoplant?




T level	Cooling capacity	Entropic load [kW @ 4.5 K]
40-300 K	65 g/s	2
40-60 K	81 kW	7
1.9 K	4.4 kW	16
Total		25






- The total entropic load is not compatible with existing LHC cryo-plants (18 kW @ 4.5 K).
- However, by adding a Turbo-Brayton refrigeration stage to produce the cooling capacity above 40 K (equivalent to 9 kW @ 4.5 K), the remaining capacity to be produced by the LHC plants is reduced to 16 kW @ 4.5 K.
→ The corresponding supercritical mass-flow at 4.6 K and 3 bar to be delivered in the tunnel is 220 g/s per sector, to be compared with 235 g/s for LHCB plants (new LHC) and with 190 g/s for the LHCA plants (Ex-LEP).
- Turbo-Brayton can also be used for precooling of the LHC plant and for sector cool-down.
- The aging of the existing LHC plants must also be taken into account (Ex-LEP plants will be 50-year old in 2040 !).
- Feasibility study to be continued !

Reminder:
Existing QRL not re-usable




	DN
B	340
C	100
D	200
E	100
F	100



Trench enlargement over 27 km!





HE-LHC: cryogenics distribution for 1/2 sector cooling



	DN
B	230
C	100
D	200
E	100
F	100
G	100


Reminder:
Existing QRL not re-usable



More rotating machinery
→ lower global availability
→ But existing LHC 1.8 K refrigeration unit can be reused (2.4 kW @ 1.8 K)




HE-LHC cryogenic layout




- 2.2 kW @ 1.8 K refrigeration unit
- Main sector cryo-plant 23 kW @ 4.5 K including 2.2 kW @ 1.8 K

Remark: specific cryoplants to be probably added at Point 1 and Point 5 for high luminosity insertion cooling ($28E34 \text{ cm}^{-2}\cdot\text{s}^{-1}$: reuse of HL-LHC cryo-plants?).



- 2.2 kW @ 1.8 K refrigeration unit
- Main sector cryoplant 23 kW @ 4.5 K including 2.2 kW @ 1.8 K

Additional 1.8-K refrigeration unit



The warm compressor stations must be located in noise-insulated surface buildings:

- Space requirement: $\sim 10 \times 30 \text{ m}^2$ per unit
- Reuse available existing space at P1, P2, P5 ?
- New buildings at P3 and P7.


The cold boxes must be located in underground radiation-free alcoves or caverns:

- Space requirement: $\sim 10 \times 10 \times 10 \text{ m}^3$ per unit
- Reuse available existing space at P1, P2, P5 ?
- New alcoves at P3 and P7.





HE-LHC electrical consumption



Point	Installed power			Nominal power		
	Main	1.8 K unit	Total	Main	1.8 K unit	Total
Point 1		0.5	0.5		0.4	0.4
Point 18	5.5		5.5	4.7		4.7
Point 2	5.5	0.5	6	4.7	0.4	5.1
Point 3		1	1		0.8	0.8
Point 4	11		11	9.4		9.4
Point 5		1	1		0.8	0.8
Point 6	11		11	9.4		9.4
Point 7		1	1		0.8	0.8
Point 8	11		11	9.4		9.4
Total	44	4	48	37.6	3.2	41

+ additional power for high-luminosity insertion cryo-plants



HE-LHC helium inventory



- Present LHC inventory (135 t)
- Main change due to cold-mass helium inventory:
→ from 25 to 33 l/m, i.e. + 28 t in total
- HE-LHC helium inventory: 163 t
- To store this additional inventory (28 t), 2 additional LHe storage vessels (120 m³ unit volume) will be required.



Two LHC LHe storage tanks at Point 18



Conclusion



- Conceptual designs of FCC-ee and HE-LHC are completed.
- For FCC-ee:
 - Two to four cryo-plants with unit capacity from 2 to 63 kW @ 4.5 K have been proposed to cover the need of the 5 machines (Z, W, H, ttbar1 & ttbar2)
 - a staging scenario is also proposed (similar to the scenario proposed for LEP2, LEP2+ & LHC).
- For HE-LHC:
 - The integration of the machine in the existing LHC tunnel imposes additional 1.8 K refrigeration units at the odd Points.
 - The unit refrigeration capacity per sector is 25 kW @ 4.5 K. the feasibility study to partially cover this need by the existing LHC plants has to continue.
 - The existing LHC distribution line (QRL) is not reusable (different cooling circuit, cell length, header diameter...).
 - LHC storage infrastructure can be re-used and upgraded by 2 new LHe storage tanks (from 6 to 8).
 - Cryogenic plants for high-luminosity insertions still to be design.



Thank you!