


ISOLDE FOM Report on week 32

Lefteris Fadakis

Root Cause Fault Time Distribution

Availability: 94%


Faults: 13



● Power Converters ● Radio Frequency ● Other ● Injector Complex

LHe level drop in cryo module 1 (XLL2)

A Series Of Unfortunate events



A/q:4.0

Cavities scaled for
A/q:4.118
Running during night
Without beam

A/q:4.0

Delivering 140Sm34+
A/q:4.118

152Sm37+
A/q:4.108

LHe lvl at 8%
in 1st cryo
module(XLL
2)

Delivering 140Sm34+
A/q:4.118

Possible conditioning

Decreased gradient
of SRF 05 to
3MV/m

Decreased the
gradient of SRF
05 by 2MV/m

Issue:

1. LHe is supplied by a main valve (2CV960) which is fixed so that the pressure and cold box is stabilized by limiting the available flow.

On Monday, we very slightly increased the field of SRF05 , which changed the power dissipation in the CM by only ~3-4W. Due to the strict margin of the valve the system could not provide enough cooling power.

2. No one realised the dropping level of LHe until it reached 8% and the LLRF amplifier interlock kicked in.

Solution:

1. Cryogenic operators adjusted the upper limit of the main valve 2CV960 from 33% to 36% to increase the margin of regulation.

2. They corrected the issue with the alarm of the LHe level which was not working at the time.

- Apart from the issues stated above we are glad to mention that we delivered beam ahead of schedule.
- According to our physics coordinator, for this year, this was the first fully completed experiment for HIE-ISOLDE.