

EUCAS 2017 3L04-04
20/Sep. /2017

Protection against the ground fault for 275 kV HTS cable and experiment

T. Takagi, M. Yagi, H. Fukushima, S. Mukoyama
(Furukawa Electric)

M. Serizawa, T. Nakano, T. Mimura
(Tokyo Electric Power Company Holdings)

1 . About experiment

- Ground fault accidents for HTS cables
- Samples of the standing style
- Results of the samples without protection


2 . Protections against the ground fault

- Behavior of the current and voltage
- Protection for the cable core and cryostat pipe

3 . Effects of protections

- Results of the samples with protection

Structure of the cable





Material & Design

Structure	Specification	Diameter (mm)
Former	400 mm ² hollow stranded copper	35.4
HTS conductor	2-layer YBCO	
Insulation	PP laminated paper	81.0
HTS Shield	1-layer YBCO	
Cu Shield	210 mm ² copper tape	88.0
Protection	Insulation paper	
Cryostat pipe	SUS and PVC sheath	150

To cancel the magnetic field due to the alternating current

Single core is stored into a cryostat pipe.
=> 3 set are needed for three-phase AC system.





=> Can this be possibly lifted up?

This presentation's theme

Sample style to examine

We have an HTS cable system to examine.





But it is too expensive to burn out....

=> We adopted the standing style.




Sample of standing style






Results (w/o protection)



Core




AC 10 kA – 3 cycles

Pipes

Inner pipe
;w/o MLI




Outer pipe



Current


- Current flowed in all 3 paths, the shield and both of the cryostat pipe.
Their amount equals to the source current.
- Current flowed in the shield at first, and in the outer pipe at last.





Voltage

- Voltage rose abruptly in around 1ms, and was relatively stable.
- Amount of the energy was approximately 0.3 MJ for 3 cycles.

Protection for core and inner pipe




Results (w/ protection)



Sample A, similar to B

Outer pipe kept its soundness
NOT reached by arc discharge



Effect of protections



Cable core




The protection on the core was severely damaged, as well as the core itself.

The protection on the inner pipe was damaged thermally, in spite of its outer soundness. (common to sample A and B)

Protection

Inner pipe



- Ground fault examinations for 275 kV HTS cable were conducted.

AC 10 ~ 20 kA, 3 cycles for samples of the standing style.

- Protection for the core and inner pipe was provided.
=> Successfully kept the soundness of the outer pipe.

The arc discharge to outer pipe was interrupted,
regardless of the protection on the core.

- Protection on the inner pipe remained,
despite that on the core damaged severely.

Protection on the core may worthless for 275 kV cable.

ACKNOWLEDGMENT

This work has been supported by the NEDO

Sample list and details

w/o protections

Sample	Current [kA]	Arc reach		Energy [MJ]	Damage of cryostat pipe
		[cycle]	Outer p.		
No.1	1.5	0.5		0.006	No damage
No.2	3	0.5		0.017	Inner pipe vented
No.3	5	0.5	v	0.033	Outer pipe vented
No.4	5	0.5		0.030	Inner pipe vented
No.5	7.5	3	v	0.214	Outer pipe vented
No.6	10	3	v	0.245	Outer pipe vented
<u>No.7</u>	10	3	v	0.325	Outer pipe vented

The arc did not revived with the voltage of 12 kV.

