



## OUTLINE:

- ❑ Motivation
- ❑ Reminder of 2009 conceptual design
  - Constraints from physics programme*
  - Contain radiation*
  - Magnets available*
- ❑ Open questions in 2009
- ❑ Update
  - Shielding and other RP requirements*
  - Controls*
  - Costs and resource requirements*
- ❑ Time line
- ❑ Conclusions

# WHY A NEW LAYOUT FOR THE EAST AREA

Triggered by ABOC/ATC days in 2007

- ❑ Splitters lead to high beam losses in critical regions
  - high radiation levels
  - no beam loss monitors!
- ❑ Catastrophic situation of magnets
  - 63 magnets of **22 different types**, many critically weak and/or **no spares**
  - need **2 weeks to open & close concrete roof shield** + cooldown + repair
  - space very tight, access extremely difficult
  - high radiation levels
  - EA has only 8% of #magnets in NA, but needs same #FTE to maintain
- ❑ No remote control for most systems (motors in particular)
  - No high level control system, no beam files
  - Grossly insufficient beam instrumentation – *somewhat improved since then*

## Recommendation: global review of East Area

**Note:** Operational difficulties with F61N.BVT01 in 2008,  
T10 only 6 GeV due to two Q800 (smoke traces!), three Q120's replaced in 2009, ...  
+ F61N.DVT01 broken, suspected problems in T7 line, ... (2009/2010)

# THE EAST AREA CONTINUES TO BE POPULAR:

20-Jan-2009

## 2009 PS Fixed Target Programme



Version 0.0

Colour code: dark blue (dark shading) = not yet allocated; yellow (light shading) = not allocatable or Machine Development

		P1	P2	P3	P4	P5	P6
		35 30 Apr 4 Jun	35 4 Jun 9 Jul	35 9 Jul 13 Aug	35 13 Aug 17 Sep	35 17 Sep 22 Oct	32 22 Oct 23 Nov
T7	Skip 7	Irradiation 35	35	30	Irradiation 35	Irradiation 35	Irradiation 32
T8	Skip 7	DIRAC 35	DIRAC 35	DIRAC 35	DIRAC 35	DIRAC 35	DIRAC 32
T9	Skip 7	TZK-ECAL 35	TZK 14 ECAL 17	CALICE RPC 14 2	COMPASS CALC 14	MICE EMF 14	NA62 16 VIPIX 9 NA62 15 PBES 17
T10	Skip 7	ALICE PVD 10 ALICE FARICH 10 ALICE MMEGAS 15	ALICE TOF 14 ALICE VHVPID 13	ALICE VHVPID 13 CMS ECM 8	ALICE TOF 15 RD51 CALICE 15	35	10 ALICE MMEGAS 10 ALICE VHVPID 7 ALICE TOF 8 ALICE TOF 7 ALICE HPTD 16 ALICE VHVPID 9
T11	Skip 7	CLOUD 35	CLOUD 35	CLOUD 35	35	35	32

To liberate PS cycles for DIRAC

and still requests being added,  
due to pressure on beam time!



This trend continues  
in 2010: 335+80 days  
requested  
in T9,T10,T11

█ = Tests  
█ = CLOUD




# BASIC PRINCIPLES FOR NEW EAST AREA

- ❑ Use fewer types of **reliable magnets** with spares
- ❑ Reduce roof shielded areas and **ease access to equipment**
- ❑ **Keep radiation restricted** to upstream areas as much as possible
- ❑ Keep T8 beam and DIRAC installed as it is until the end of DIRAC, or for IRRAD in case they take over the DIRAC location
- ❑ Replace SMH1 and F61S.BHZ1 by two MCB magnets in PPM mode, i.e. no more splitter (*F61S.BHZ01 replacement already done*).
- ❑ Could also serve IRRAD as now, through air, however not from ZT7.BHZ01 but from F61S.BHZ02
- ❑ **Design new beam(s)** to 1 (or 2) “North target” marguerite(s)
  - *two decoupled beams, but at the cost of cycle efficiency*
  - *two beams coupled by “wobbling station”, coupled but higher cycle efficiency*
- ❑ Test beams can provide **pure** hadron and muon secondary beams up to 15 GeV/c and pure (> 95%) electron beams from  $\gamma$  conversion (up to about 10 GeV/c)


*Inspired by and similar in spirit to West Area rebuild in the end of the 1990's!*

Uses "dummy magnets"

~5x better transmission than present lines!




# SCHEMATIC LAYOUT OF NEW EAST AREA PRIMARY BEAM FRONTENDS



1.00MR

1.00PC




DIRAC OPTICS 2008

1.00MM

1.00MR

1.00PC




30.00 MM  
5.00 M



1.00MR

1.00PC




DIRAC OPTICS V2011-01

**Not significantly different from 2008**

1.00NM

1.00MR


1.00PC



**Different central trajectory**



**+ changes of magnet types**

### Horizontal



NORTH BRANCH OPTICS V.2011-01


### Vertical




# SECONDARY BEAM




# OPTICS FOR "T9++ BEAM" – UP TO 15 GeV/c




OPTICS FOR NEW EAST AREA TEST BEAM T9





*Even better transmission than generic optics!*



# SECONDARY BEAM OPTICS FOR "T10++ BEAM" – UP TO 12 GeV/c





OPTICS FOR NEW EAST AREA TEST BEAM T10



# SCHEMATIC LAYOUT OF THE TWO SECONDARY BEAMS

(inspired by “West Area 2000” approach)





## Magnets for new East Area

Type	# Avail	Locations where used										Used	#Spares
MCB	10	BP.BHZ1	BP.SMHI	BS.BHZ1	BS.BHZ2	BD.BHZ1	BD.BHZ2	BP.BHZ1	BN.BHZ2	+Spares at SPS		8	2
M100SP	4	B1.BVT1	B2.BVT1			Red shading						2	2
M105	3	BS.DHZ1	BN.DHZ1			Red shading						2	1
M200SP	10	B1.BHZ1	B1.BHZ2	B2.BHZ1	B2.BHZ2							4	6
MC200	7	BN.BVT1										1	6
MEA19	8	BP.DVT1	BP.DVT2									2	6
MNPA25	6	BP.DHZ1	BN.DVT1									2	4
MNPA30	7	BS.DVT1	BD.DVT1									2	5
Q100	17	B1.QDE6	B1.QDE8	B2.QDE6	B2.QDE8	B2.QDE8b						5	12
		Spares at SPS											
Q120	7	BP.QDE02	BN.QDE1	BN.QFO2	B1.QDE2	B2.QDE2						5	2
Q200	5	BD.QDE1	BD.QFO2	B1.QFO7	B2.QFO7					Spares at SPS		4	1
Q600	9	BP.QDE4										1	8
QFL	5	BP.QFO03	BS.QFO1	BS.QDE2								3	2
QFS	10	B1.QFO4	B1.QFO5	B2.QFO4	B2.QFO5							4	6
QDS	12	B1.QFO1	B1.QFO3	B2.QFO1	B2.QFO3							4	8
Q74	2 (?)	BP.QFO01										1	1
MDX	10	B1.DVT1a	B1.DVT1b	B2.DVT1a	B2.DVT1b	B1.DHZ1	B2.DHZ2					6	4
MEJ15	3											0	3


BP = Primary line  
BD = DIRAC beam line

BN=North branch  
BS=South branch

B1 = Secondary beam #1  
B2 = Secondary beam #2

Green shading = spares  
Red shading = unavailable

# And this is how it looks 'on the floor':



EHNL "2011"

Y. BONNET  
16/02/2009  
Scale 1:200


0 5 10m

T1 LINE: E:\ps\...  
T2 LINE: E:\ps\...  
T3 LINE: E:\ps\...  
T4 LINE: E:\ps\...  
T5 LINE: E:\ps\...


East Hall of PS




### Old layout:



### New layout:



# Proposed layout, 2010 version:





Apron

PORTE 19

# EAST HALL

(Bldg. 167)

Primary zone

Intermediate zones


T10

79

X = 2150  
Y = 2200

HALL

PORTE 18



Secondary beam zones & experimental areas


T10  
12 GeV

TESTS

T9 CLOUD  
16 GeV

24 GeV

DIRAC



bean catcher

SHUTTLE

PORTE 113



# What does this mean (2009 slide) ?

- ❑ Compatibility with requirements from DIRAC/IRRAD and CLOUD
- ❑ More flexible and better test beams, but (effectively <) 1 less  
*Higher top momenta, small production angles, choice of particle type*
- ❑ Only use agreed 'healthy' magnets with sufficient spares  
*All magnets and rectifiers exist – reduced cost*
- ❑ Primary beam is dumped almost immediately after target  
*High (also induced) radiation levels restricted to minimal areas*
- ❑ Very restricted number of magnets is under heavy roof shielding  
The ones in a limited zone following the primary area have only a thin roof shield.  
Many have no roof shielding.  
*RP simulations are required to see whether the latter shield can be avoided*
- ❑ Restricted material cost but lots of reshuffling of lines and shielding

# Questions left open last year

- ❑ Radioprotection studies to confirm reduction of shielding
- ❑ Costs, resources
  - Transport and handling
  - Magnets and rectifiers + infrastructure
  - Instrumentation, controls
  - Vacuum
  - Radioprotection
  - .....
- ❑ Timeline

# Transport and handling resources

Activity	Time (months)
Roof dismantling	1.5
Magnets removal	0.5
Wall removal (T7, T10, T11)	0.5
Install new walls	1
Install concrete platforms under magnets	1
Install new magnets	1
Install new roof	1
<b>Total</b>	<b>6.5 months</b>

Estimate assumes a team of 3 persons

**Hence required ~ 20 man months**

## Cost for rectifiers and magnets:

Item	Cost (kCHF)
5 Rectifiers (4 +1 spare)	185
Rectifier Re-cabling, controls, installation, FGC3	45
Magnet refurbishment material+labour	97
Cabling of magnets	130
Hydraulic connections (reusing tubes)	20
<b>Total</b>	<b>477</b>

*The PO group recommends this even if we do not change the layout*

*On the longer term a more complete consolidation / renovation of the old rectifiers in the East Area will become necessary. A full consolidation might cost ~ 2.8 MCHF. Again, independently of whether the layout is changed or not.*



# POWER SUPPLY REQUIREMENTS PRIMARY BEAMS

Preliminary

Magnet	$I_{max}[A]/V_{max}[V]$	TB	Rectifier
<b>PRIMARY LINE</b>			
BP.QFO1	650	24	R2g.06
BP.DHZ1	600/60	27	R2g.07
BP.QDE2	400/80	14	R1.14
BP.DVT1	250/70	20	T1b.04pp
BP.DVT2	250/70	8	R1.15
BP.QFO3	400/40	28	R1.16
BP.BHZ1	600/120	5	R2g.08
BP.QDE4	350/140	7	R2g.09
<b>SOUTH BRANCH</b>			
BS."SMH1"	500/100	16	R2b.02
BS.BHZ1	300/50	10	R1.18
BS.QFO1	400/40	12	R1.17
BS.QDE2	400/40	21	R2b.04
BS.DHZ1	180*	301	T1b.01pp
BS.DVT1	600/80	2	R2b.05
BS.BHZ2	800/150	9	R3.02

Magnet	$I_{max}[A]/V_{max}[V]$	TB	Rectifier
<b>DIRAC LINE</b>			
BD.BHZ1	400/80	92	R2g.01
BD.BHZ2	400/80	93	R2g.02
BD.DVT1	200/40	302	T1b.05pp
BD.DHZ1	480*/30	303	T1b.03pp
BD.QDE1	500/100	103	R2g.03
BD.QFO2	500/100	105	R2g.04
SPECTRO	2500		R6.01
<b>NORTH BRANCH</b>			
BN.QDE1	250/50	30	R10.01
BN.QFO2	300/60	17	R3.03
BN.DVT1	400*/60	15	R3.04
BN.BHZ2	800/100	1	R3.05
BN.BHZ3	880/200	25	R2b.06

\*) Same limit as before

En rouge: nouveaux convertisseurs  
À fabriquer

Courtesy J.L.Blanc

# POWER SUPPLY REQUIREMENTS SECONDARY BEAMS

Preliminary

Magnet	$I_{max}[A]/V_{max}[V]$	TB	Rectifier
<b>“T9 BEAM”</b>			
T9.DHZ1	240/150	33	R2.01
T9.QFO1	350/25	34	R2.02
T9.QDE2	350/80	36	R2.03
T9.QDE3	350/25	49	R2.04
T9.BHZ1	600/150	38	R2G.10
T9.QFO4*	350/30	53	R2.05
T9.QFO5*	350/30		
T9.BHZ2	600/150		R2G.05
T9.QDE6	700/150	44	R2B.01
T9.BVT1	450/120	31	R2.06
T9.QFO7	600/120		R2B.07
T9.QDE8	700/150	50	R2B.03
T9.DHZ1	240/80	43	R2.07
T9.DVT2	240/80	41	R2.08

Magnet	$I_{max}[A]/V_{max}[V]$	TB	Rectifier
<b>“T10 BEAM”</b>			
T10.DHZ1	240/150	89	R2.09
T10.QFO1	400/30	66	R2.11
T10.QDE2	450/80	48	R2.12
T10.QDE3	400/30	52	R2.13
T10.BHZ1	750/200	51	R3.07
T10.QFO4*	500/50	54	R2.14
T10.QFO5*	500/50		
T10.BHZ2	750/200	59	R3.08
T10.QDE6	600/150	32	R3.01
T10.BVT1	600/150	55	R3.06
T10.QFO7	600/150		R2B.08
T10.QDE8	400/160	56	R2.15
T10.DHZ1	240/80	60	R2.16
T10.DVT2	240/80		R2.10

En orange: redresseurs déplacés du ERB3 à EGB

\*) Could be connected in series


55 alimentations (53 avec aimants en série)

Courtesy J.L.Blanc

# SHIELDING AND RP ISSUES

Carefully studied by Thomas Otto / RP

- Thickness of shielding 2.4 m (as shown before)
- Height of walls > 4 m to reduce sky-shine
- No roof shielding required**
- Optimise access chicane
- Optimise target design (shielding vs intervention time)



- Side shielding thickness 6 to 6.4 m (as now)
- 2.4 m roof shielding, i.e. 0.8 m Fe + 1.6 m Concrete
- Need ventilation (cf nTOF target area)
- Optimise entrance chicane

# Cost of Ventilation

Th.Otto requests a ventilation system for the small primary zone, similar to the one implemented for the nTOF target area.

This would also evacuate Ozone from the area, which now stays and affects the equipment in that zone (corrosion of magnets etcetera).

Evacuation of the extracted air via the roof of B157

For the cost we quote the cost of the nTOF installation as an example

Item	Cost
Cost of nTOF cooling station	35 keuro
Ventilation monitoring station	50 keuro
<b>Total</b>	<b>130 kCHF</b>

It would probably reasonable to to foresee a ventilation for the primary area even if the layout would not be changed

# Cost of Vacuum

Item	Cost (kCHF)	FTE
Chambers (~50 x 2.5 kCHF)	125	
Windows	10	
Controls	50	
Manpower (2x1 month FSU + staff)	20	0.2
<b>Total</b>	<b>205</b>	<b>0.2</b>

***To be confirmed***

# Other Costs

Item	Cost	FTE
Modifications access doors	40 kCHF	
Survey work 2.1 months x 2 persons		0.4
Radioprotection 1 technician during dismantling, 0.5 technician during remounting		0.5+0.25
Radioprotection infrastructure	20 kCHF	0.1
Beam instrumentation *)	10 kCHF	0.1
Upgrade threshold counters to NA standard *)	20 kCHF	0.2
Displacement T9/T10 gas zone	50 kCHF	
Coordination, superintendance, project management		0.5

\*) Based on 2004 estimate in the framework of Renovation Programme Committee

## Side remark (2009 slide):

In 2005 a proposal was made to **upgrade the controls** of the East Area.  
For the moment in the East Area there is:

- no remote control / readout of collimators
- control of magnet currents only by working sets and knobs
- no easy and convenient beam files
- no remote reading of access system and vacuum state
- no user applications for reading of beam instrumentation

*However, one delay wire chamber + a scintillator were added per beam since then*

It seems that this could be an occasion to **migrate the East Area controls to Cesar** (i.e. the recently upgraded North Area controls).

At the time the resource estimate (excluding DWC + scints) were about 80 kCHF for VME crates + Cerenkov upgrades plus a number of man months on the software side. Now part of this upgrade has been done already (timing, VME).

# Cost of controls upgrade

Item	COST	
Motorisation upgrade (PLC + FESA gateway) for 6 COLLS + 2 absorbers + 2 converters	< 80 kCHF	EN-STI
CESAR extension to East Area, depending on experience of the person (without general CESAR consolidation also for NA)	0.5-1 FTE	BE-CO
Full consolidation also for NA CESAR *) (NETBEANS replacement, integration with LSA, ..)	0.5 - 1 FTE	BE-CO
PC's in user barracks	< 10 kCHF	
<b>Total</b>	<b>90 kCHF + 0.5-2 FTE</b>	

\*) Independent of East Area project but considered useful by BE-CO to combine the two



# Summary of costs:

Item	Specific cost		Useful anyway	
	Material	FTE	Material	FTE
Transport and handling		0.85		
Rectifiers	45		185	
Magnets, cabling, cooling	250			
Ventilation			130	
Vacuum (incl. FSU)	205	0.2		
Access	40			
Survey		0.4		
Radioprotection	20	0.85		
Controls			90	0.5-2
Other costs (BI, gas, ...)	80	0.3		
Project management		0.5		
<b>Total cost</b>	<b>640</b>	<b>3.1</b>	<b>410</b>	<b>0.5-2</b>

**Grand total: ~ 1050 kCHF + ≤ 5 FTE**

## Consolidation of East Area recommended independent of this project


- ❑ Ventilation of primary area would reduce Ozone impact on magnets anyway
- ❑ Replacement of old rectifiers (R2A and R2) to be considered anyway and of most rectifiers in the not too distant future
- ❑ Upgrade of controls would be a good thing even in case of no layout change
- ❑ In the long term migration from ARCON to RAMSES-2 will become necessary  
Approximate cost 300 kCHF, foreseen in consolidation project.  
The migration to Ramses-2 should be kept in mind during the installation work of this project.
- ❑ The air conditioners are mostly in a pitiful state and need replacement

# Proposed time line (2009)

- ❑ CLOUD changes from Mk2 to Mk3 module **in 2011 (tbc)** → **2012+?**  
This requires a larger beam and a larger zone (T11 → T9B zone)  
It seems reasonable to synchronize the EA modifications with this change
- ❑ **DIRAC / IRRAD** future not well understood at this moment  
but new design is essentially decoupled from this question

**Run in 2010 “certain”**

**Will request run in 2011 (long-lived atoms)**

 Rebuild of parts inside PS and of primary zone in **shutdown in 2010/11**,  
provided CLOUD has completed its Mk2 program

Continue construction of test beams during the 2011 run  
Could probably continue operation of DIRAC during 2011 with  
some additional local shielding at exit of the primary zone

Total duration of project: **first estimates 8-12 months**

**2011/12?**



## Taking into account

- ❑ The timescales of CLOUD and DIRAC as they are known today,
- ❑ The recent announcements concerning a long LHC run, i.e. (to my understanding) no long shutdown in 2010/11,
- ❑ That the management is launching studies how to prolong the lifetime of the of the present injector complex (including the PS) by at least another 15-25 years

it seems that **starting the work end 2011/early 2012** could be a convenient option. It could then be completed in time for the 2013 start-up

**The duration of the work has been estimated to be less than one year (9 months),  
The part affecting PS operation within 4 months**

# CONCLUSIONS

- ❑ The design of a new East Area layout presented at the previous IEFC workshop has been validated (with very minor modifications) in terms of its radioprotection merits
- ❑ It uses reliable equipment and improves greatly their accessibility and maintainability
- ❑ The cost is around 1 MCHF + 4-5 FTE, even including some changes which should even be considered if the layout is not changed.
- ❑ The change can be done within one year, with at most 4 months stop for the PS, and the year 2012 seems a possible period in terms of the East Area physics prospects and the latest planning for LHC operation and shutdowns.
- ❑ A non-exhaustive list has been shown of some items that need further consolidation if the East Area has to be operated for another 15-25 years or more.


**Thanks to all who have helped in preparing this work.  
Particular mention to:**

Vito Baggiolini, Yves Bernard, Jean-Luc Blanc, Dominique Bodart,  
Yannick Body, Jan Hansen, Michael Lazzaroni, Gilles Le Godec,  
Patrick Lelong, Alessandro Masi, Robert Mollay, Thomas Otto,  
Jens Spanggaard, Davide Tommasini, Giovanna Vandoni, Markus Widorski,


...

**Spare slides**

# TURTLE SIMULATION (for $C1_{ACCV}=C2_{ACCH} = \pm 40$ mm, $C3_{\Delta P} = \pm 1$ mm)




**X in mm**



**Y in mm**





# COMPLETE RECTIFIER CONSOLIDATION – Part I

Logical Name	Designation Imax(A)/Umax(V) calcul selon caractéristiques Aimants	Last upgrade	Next upgrade	Consolidation Cost (CHF) 2009 ESTIMATION
<b>PRIMARY LINE</b>				
BP.QFO1	650	20 ans	Consolidation type SPS (1000A/220V)	30000
BP.DHZ1	600/60	20 ans	Consolidation type SPS (1000A/220V)	30000
BP.QDE2	400/80	20 ans (Thyristors)	Changement car bobinages d'origine	35506
BP.DVT1	250/70	30 ans	Changement	35855
BP.DVT2	250/70	20 ans (Thyristors)	Changement car bobinages d'origine	35506
BP.QFO3	400/40	20 ans (Thyristors)	Changement car bobinages d'origine	35506
BP.BHZ1	600/120	20 ans	Consolidation type SPS (1000A/220V)	30000
BP.QDE4	350/140	20 ans	Consolidation type SPS (1000A/220V)	30000
<b>SOUTH BRANCH</b>				
BS.*SMH1*	500/100	20 ans	Consolidation type SPS (1000A/220V)	30000
BS.BHZ1	300/50	20 ans (Thyristors)	Changement car bobinages d'origine	35506
BS.QFO1	400/40	20 ans (Thyristors)	Changement car bobinages d'origine	35506
BS.QDE2	400/40	30 ans	Changement	22943
BS.DHZ1	180*	30 ans	Changement	35855
BS.DVT1	600/80	30 ans	Changement	22943
BS.BHZ2	800/150	30 ans	Changement	81648
<b>DIRAC LINE</b>				
BD.BHZ1	400/80	20 ans	Consolidation type SPS (1000A/220V)	30000
BD.BHZ2	400/80	20 ans	Consolidation type SPS (1000A/220V)	30000
BD.DVT1	200/40	30 ans	Changement	35855
BD.DHZ1	480*/30	30 ans	Changement	35855
BD.QDE1	500/100	20 ans	Consolidation type SPS (1000A/220V)	30000
BD.QFO2	500/100	20 ans	Consolidation type SPS (1000A/220V)	30000
SPECTRO	2500	15 ans	Consolidation type SPS	60000
<b>NORTH BRANCH</b>				
BN.QDE1	250/50	30 ans	Changement	19639
BN.QFO2	300/80	20 ans	Consolidation type SPS (800A/300V)	30000
BN.DVT1	400*/60	20 ans	Consolidation type SPS (800A/300V)	30000
BN.BHZ2	800/100	20 ans	Consolidation type SPS (800A/300V)	30000
BN.BHZ3	880/200	30 ans	Changement	103928
<b>"T9 BEAM"</b>				
T9.DHZ1	240/150	30 ans	Changement	38241
T9.QFO1	350/25	30 ans	Changement	15686
T9.QDE2	350/80	30 ans	Changement	32641
T9.QDE3	350/25	30 ans	Changement	15686
T9.BHZ1	600/150	20 ans	Consolidation type SPS (1000A/220V)	30000
T9.QFO4*	350/30	30 ans	Changement	38241


# COMPLETE RECTIFIER CONSOLIDATION – Part II

T9.QFO5*					
T9.BHZ2	600/150	30 ans	Changement	68113	
T9.QDE6	700/150	30 ans	Changement	75060	
T9.BVT1	450/120	30 ans	Changement	49371	
T9.QFO7	600/120	30 ans	Changement	59181	
T9.QDE8	700/150	30 ans	Changement	75060	
T9.DHZ2	240/80	30 ans	Changement	25736	
T9.DVT1	240/80	30 ans	Changement	25736	
<b>"T10 BEAM"</b>					
T10.DHZ1	240/150	30 ans	Changement	38241	
T10.QFO1	400/30	30 ans	Changement	19140	
T10.QDE2	450/80	30 ans	Changement	38241	
T10.QDE3	400/30	30 ans	Changement	19140	
T10.BHZ1	750/200	15 ans	Consolidation type SPS (800A/300V)	30000	
T10.QFO4*	500/50	30 ans	Changement	30392	
T10.QFO5*	500/50				
T10.BHZ2	750/200	15 ans	Consolidation type SPS (800A/300V)	30000	
T10.QDE6	600/150	15 ans	Consolidation type SPS (800A/300V)	30000	
T10.BVT1	600/150	15 ans	Consolidation type SPS (800A/300V)	30000	
T10.QFO7	600/150	15 ans	Consolidation type SPS (800A/300V)	30000	
T10.QDE8	400/160	30 ans	Changement	54948	
T10.DHZ2	240/80	30 ans	Changement	25736	
T10.DVT1	240/80	30 ans	Changement	25736	
<b>Total (CHF)</b>				<b>1942379</b>	
<b>Proposition Consolidation (CHF)</b>				<b>2000000</b>	
<p>==&gt; les prix de consolidation sont basés sur une optimisation des caractéristiques des convertisseurs par rapport au besoin utilisateur ce qui n'est pas le cas actuellement (surdimensionnement). Le budget pourrait être revu à la hausse si une flexibilité est demandée</p> <p>En suspend: Patch Panel + Simatic ==&gt; Intérêt de conserver le système?</p>					
<b>Consolidation infrastructure (Câbles AC/DC/Contrôle)</b>					
<b>Estimation (CHF)</b>				<b>800000</b>	
<b>TOTAL (CHF)</b>				<b>2800000</b>	

**i.e. cost up to about 2.8 MCHF**

# BEAM LOSSES IN SECONDARY BEAMS

*This beam gives losses similar to the other beam*



# Survey manpower

Assume a team of 2 persons

Item	Time (months)
Creation of new references in zone	0.2
Trace beam lines and equipments on floor	0.2
Define positions of the walls	0.2
Alignment of beam lines	1.5
<b>Total</b>	<b>2.1</b>




**Total FTE: 4.2 man months**

**Best resumed in the following table :**

Device	Evolution	Number	Priority	Cabling	Software	Remark
MWPC	discard	5	High		none	obsolete
DWC	new	5	High	~ 5..10 k	heavy	replace MWPC
Magnets	no mod	36	-	-	exist/collect	
Beam stoppers	no mod	5			collect state	not AB
Collimators	none	9 (x2)	High	exist	to middleware	need PLC
Vacuum	none				collect state	AT/VAC
Cerenkov	automate	5	Low	~ 5 k	same as EHN	VME interface
Beam counter	new	5	high	see DWC		
Workstation	new	~8	medium	local	standard	physicist access

**Estimated effort to invest for renovation.**

Devices	Hardware cost	Manpower/hard	Manpower/soft
MWPC/DWC/beam counters	~ 20 k	~ 1 man*month	~ 2 man*month
Collimators	~ 20 k	<< 1 man*month	> 2 man*month
Cerenkovs	~ 10 k	~ 2 man*month	
Magnets	none	none	< 1 man*month



**Radiation Survey Measurements  
East Experimental Area - Target Zone**

Ambient dose equivalent rate  
measured at 40 cm distance in  $\mu\text{Sv/h}$

Beam stop: 07.12.2009  
Remark: None

Date: 21.01.2010