





ABOC/ATC days




Electrical Network: Selectivity and Protection Plan




José Carlos GASCON
TS-EL Group

22 January 2007



Summary


- ❖ Introduction
- ❖ Selectivity
- ❖ CERN HV electrical
- ❖ 29th July 2006
- ❖ Selectivity at CERN
- ❖ Project Planning




Introduction

⇒ Protection system in the electrical network

- ❖ Switchgear: in charge of clearing faults
- ❖ Sensors: providing measurements to detect faults
- ❖ Protective relays: processing measurements and ordering to clear faults






Introduction

⇒ Why protection system is needed

- ❖ Personnel safety against electrical hazards
- ❖ Avoid equipment stress: thermal, electrical and mechanical damages
- ❖ Assure network stability
- ❖ Clear electrical faults and maintain service continuity

⇒ Features of protection system

- ❖ Fast
- ❖ Reliable
- ❖ Selective




Selectivity

⇒ Definition

- ❖ Discrimination between protection systems, isolating a faulty area of the electrical network as quickly as possible and leaving all the fault-free areas energized

⇒ How to do


- ❖ Time based discrimination
- ❖ Current based discrimination
- ❖ Logic discrimination
- ❖ Directional protection discrimination
- ❖ Differential protection discrimination
- ❖ Combined



Selectivity


⇒ Parameters

- ❖ The complexity and size of the electrical network
- ❖ Network architecture
- ❖ Existing sources and their response in the event of a fault
- ❖ Operating time of each protection system
- ❖ Backup time
- ❖ Compromise continuity of service vs. degree of protection





Selectivity: examples

Radial distribution



Loop distribution (ex.: SPS)






CERN HV Electrical Network

⇒ Complexity

- ❖ Voltage levels: 400kV, 66kV, 20kV, 18kV and 3,3kV
- ❖ 94 HV substations: 38 LHC, 26 SPS and 30 Meyrin
- ❖ About 1,000 protective relays and switchgears
- ❖ 4 sources: EDF (400kV & 20kV), EOS and Diesel Generators
- ❖ 3 different interconnected networks by site:
 - LHC: Machine, General Services and Safety (Assured)
 - SPS: Pulsed, Stable and Safety (Assured)
 - Meyrin: Pulsed, General Services and Safety (Assured)
- ❖ Sites interconnected by 18kV links
- ❖ Power flow direction depending on the configuration
- ❖ Compensators and harmonic filters
- ❖ Diversity of loads: pumps, converters, dipoles, transformers, compressors




CERN HV Electrical Network


⇒ Protection system

- ❖ Switchgears from all ages: specific clearing time for each generation
- ❖ Different technologies in protective relays
40% digital, 40% electronics and 20% electromechanical






29th July 2006 (I)




1st fault events

- ❖ 1 ph. fault detected in neutral reactance
- ❖ 3 ph. detected by all prot. but blocked
- ❖ Protections trip 66kV and 130kV sources




29th July 2006 (II)



2nd fault after “autotransfer system”

- ❖ 3 ph. detected by all prot. but blocked
- ❖ Protection trips at 66kV source




29th July 2006: consequences

⇒ Power cuts


- ❖ LHC General Services
- ❖ SPS Stable loop
- ❖ North Area Stable loop
- ❖ Meyrin site: West Area and PS, ISOLDE and Administrative loops


⇒ After analyse of the event

- ❖ Difficult selectivity between 66kV and 18kV levels
- ❖ Backup time not adapted for this scenario
- ❖ If selectivity, power cut reduced to the Meyrin site and lower reestablishment time



29th July 2006: selective






Selectivity at CERN

⇒ Implemented selectivity

- ❖ 400kV backup agreed with EDF
- ❖ LHC General Services and Machine
- ❖ SPS pulsed and stable loops
- ❖ PS, ISOLDE and Administrative loops

⇒ Non-selective areas (tripping 66 kV)

- ❖ Autotransfert system (BE9, SEM12 and ME9 substations)
- ❖ West Area
- ❖ North Area
- ❖ LHC-1 and LHC-5 (in project)




Planning (I)

⇒ **Activities in progress**

- ❖ Catalogue of protective relays: 60% completed
- ❖ Short circuit calculations: under approval

⇒ **Selectivity Phase 1 (April 2007)**

- ❖ Selectivity study for the non-selective areas
- ❖ Data base for all protective relays installed
- ❖ Provisional solution for the non-selective areas



Planning (II)

⇒ **Selectivity Phase 2 (January 2008)**

- ❖ Definitive solution for non-selective areas
- ❖ Complete selectivity map for main substations and configurations
- ❖ Implementation
- ❖ Commissioning

⇒ **Selectivity Phase 3 (in the course of 2008)**

- ❖ Selectivity map for the whole CERN HV network
- ❖ Transient simulations for main substations (BE, BE9, ME10, ME9, SEM12)




ABOC/ATC days



Electrical Network: Selectivity and Protection Plan

Questions?



José Carlos GASCON
TS-EL Group

22 January 2007