

Option to feed the Corrector Package correctors with Water cooled cable following TCC 01/11/2018

*G. D'Angelo, P. Fessia, J.-C. Guillaume, S. Yammine, F.
Rodriguez Mateos*

Short summary

- TCC endorse the removal of the 120 A and 200 A SC wires from the SC link
- The connection of the CP (where the related magnet are connected) to the PC and the PC location itself is still pending
- The following options were discussed
 - Case A: use to standard warm cable leaving the PC on the HL UR. The cables would run through the HL ULs and SC link core. This had to be reviewed because the core modification to allow the warm copped cable to cool in air and the CV installation in the UL had not been foreseen
 - Case A': the update version of the Case A
 - Case B: installation of the PC in the LHC service galleries around the IPs
- On the 01/11/2018 following the presentation it was asked to analyze the Water Cool Cable option Case A''

	CASE A	CASE A'	CASE B
WP3	- 40 kCHF + 95 kCHF	- 40 kCHF + 95 kCHF	- 40 kCHF + 95 kCHF
WP6a	- 450 kCHF	- 450 kCHF	- 450 kCHF
WP6a		+3 m SC link for 90 in	
WP6b	No extra cost	No extra cost	+ 75 KCHF
WP7	- 25 kCHF	- 25 kCHF	No extra cost
WP9	- 60 kCHF	- 60 kCHF	- 60 kCHF
WP15	Minor impact	Minor impact	+ 100 kCHF
WP17.1		+128 kCHF core mod	
WP17.2	+ 330 kCHF	+ 286 kCHF + vertical core inst cost	+ 62 kCHF
WP17.3		+200 kCHF UL cooling	
Total saving	- 575 kCHF	- 575 kCHF	- 550 kCHF
Total cost	425 kCHF	709 kCHF	232 kCHF
Net	- 150 kCHF	134 kCHF	- 318 kCHF (-218 kCHF)

Plus saving in magnet test
(not quantified)

Op. cost electricity
between 15 to 45 kCHF
over 10 years (depending
from kWh cost). Indicative
evaluation WP6b


Op. cost + 80 kCHF

Provision in case of need

**(38 kCHF already
in baseline)**

Option 2 :

POINT 1



3 racks PC 120 A
(R2E design) , (8 pc).

1 rack spare
contrôle
(RYSC01)


1 rack PC 200 A
(R2E-LHC600A-10V)

2 racks spare
modules
(RYSA01-RYSA02)

¼ rack energie
extraction
for 200A → 1 rack

Baseline location
(140 m cables)

Location to place
PC
@LHC zone



IP1 R

8 racks It's possible !

HL_LHC
STUDY

QH : 14
racks

Debitmetre
DFBX

EXISTING LHC
Interlock rack CYCIP01

2 racks spare modules
(RYSA01-RYSA02)

UL16

UJ16

TYCFL0
1 SPARE
2 SPARE
3 BY01

QYC01
QYC02
TYCFL01
RYSA01
RYSA02

GEOPHON
E

Displace geophone
Not recommended!

½ rack energie
extraction
for 200A → 1 rack

1 rack PC 200 A
(R2E-LHC600A-10V)

3 racks PC 120 A
(R2E design) , (8
pc).

GEOPHONE



View along F

1 rack spare
contrôle (RYSC01)

(As
now)

EXISTING LHC
RACKS QYC03-
04

QH : Quench heaters power supplies

UJ1
6

UL16

IP1 L

8 racks It's possible !

HL_LHC
STUDY

UJ14

QYC01
QYC02
TYCFL01
RYSA01
RYSA02

TYCFL0
1 SPARE
2 SPARE
3 BY01

QH : 14 racks

½ rack energie
extraction
for 200A → 1 rack

1 rack PC 200 A
(R2E-LHC600A-10V)

3 racks PC 120 A
(R2E design) , (8 pc).

Variante possible also !

UL14

EXISTING LHC
Interlock rack
CYCIP01

2 racks spare
modules
(RYSA01-RYSA02)

EXISTING LHC
RACKS QYC03-
04


1 rack spare
contrôle (RYSC01)

(As

Power cables routing from PC to CP


IP1 R

This part of the routing have to be studied more in details



Option 2 :

POINT 5



Option 2 :

IP5 R

PLACE 14 QH racks in
UJ56

8 racks It's possible
!

1 rack PC 200 A
(R2E-LHC600A-10V)

(R2E design) , (8 pc).

extraction
for 200A → 1 rack

1 rack spare
contrôle (RYSC01)

(As
now)

2 racks spare
modules
(RYSA01-RYSA02) (As
now)

UL55
7

Free space
!

IP5 L

Option 2 :

IP5 L

8 racks It's possible !

USC55

1 rack PC 200 A

3 racks PC 120 A

½ rack energie extraction for 200A → 1 rack

QH : 14 racks


(As now)
1 rack spare contrôle (RYSC01)

(As now)
2 racks spare modules (RYSA01- RYSA02)

Free space (3 racks)


Power cables routing from PC to CP

IP5 R





Power cables routing from PC to CP

IP5 L



WCC




Max length of
power cables
≈ 115 -120m


For HL-LHC: DC water cooled lines 200 and 120A

Technical solution:

ACC: Air cooled cables
WCC: Water cooled cables



Installation in cable trays



Exemple



Termination

(X 9 per half point
= 2160m/half point
=> total: 8640m)

Some consideration on ELQA and space


- We would have a WCC cable length per circuit between 200 m and 250 m
- This would lead to a leakage current $\gg 100 \mu\text{A}$ per circuit to be compared with the typical $5 \mu\text{A}$ that need to be measured ($1\mu\text{A}$ for MCBC circuits $\rightarrow 10\mu\text{A}$ for MCBY)
- Human intervention in the LHC tunnel will be necessary to act on the junction box between the WCC and the standard cable that will be connected to the current leads on the CP
- The junction box will be near the D1, a complex area with not negligible radiation (much larger respect the UJs and ULs)

For HL-LHC: DC water cooled lines 200 and 120A

To be developed and
not costed here

Technical solution:


ACC: Air cooled cables
WCC: Water cooled cables



(X 9 per half point
= 2160m/half point
=> total: 8640m)



Installation in cable trays



Example



Termination

Advantage: 0% -> 10% of thermal loads remaining in the UR, UL, cores and LHC tunnel.

Disadvantages: High bending radius for the cables, risk of crushing the cable during installation, special manufacture

need more place -> C. trays more larger.

Need of water -> risk of water leakage

-> Water interfaces

Need interlock cable to verify that the cable is correctly cooled.

Price: High level.

Ex: Pt 3 LHC: 800A; 3 lines DC 500mm² WCC from UJ32 -> SS pt3: 4.5 km; price 0.9 MCHF @2005 ~ actually: 1.2 MCHF (260CHF/m)

For 200A: 36 lines 120mm² (~100CHF/m) and 8.64km: -> **0.8 MCHF (very preliminary approach).**

	CASE A' Cu cable	CASE A'' WCC	CASE B
WP3	- 40 kCHF + 95 kCHF	- 40 kCHF + 95 kCHF	- 40 kCHF + 95 kCHF
WP6a	- 450 kCHF	- 450 kCHF	- 450 kCHF
WP6a	+3 m SC link for PC int.	+3 m SC link for PC int.	
WP6b	No extra cost	No extra cost	+ 75 KCHF
WP7	- 25 kCHF	- 25 kCHF	No extra cost
WP9	- 60 kCHF	- 60 kCHF	- 60 kCHF
WP15	Minor impact	Study to be performed	+ 100 kCHF
WP17.1	+128 kCHF core mod		
WP17.2	+ 286 kCHF + vertical core inst cost	+ 760 kCHF + connection boxes	+ 62 kCHF
WP17.3	+200 kCHF UL cooling	Valve systems	
Total saving	- 575 kCHF	- 575 kCHF	- 550 kCHF
Total cost	709 kCHF	>855 kCHF (~1 MCHF)	232 kCHF
Net	134 kCHF	>280 kCHF (~450 kCHF)	- 318 kCHF (-218 kCHF)

Plus saving in magnet test
(not quantified)

Op. cost electricity
between 15 to 45 kCHF
over 10 years (depending
from kWh cost). Indicative
evaluation WP6b

Op. cost + 80 kCHF
Provision in case of need

**(38 kCHF already
in baseline)**

Previous presentation 01/11/2018

Necessary actions and impact evaluations to leave the 120 A and 200 A PC (correctors in the CP) in the HL-LHC UR gallery

*F. Borralho, A. Broche, P. Cardon, P. Fessia, J.C. Guillaume,
S. Maridor, M. Martino, P. Mattelaer, A. Mejica, S. Yammine. F.
Rodriguez Mateos*

Cost evaluation

Amalia Ballarino et al.
TCC 20/09/2018

	CASE A	CASE B
WP3	- 40 kCHF + 95 kCHF	
WP6a	- 450 kCHF	
WP6b	No extra cost	+ 75 KCHF
WP7	- 25 kCHF	No extra cost
WP9	- 60 kCHF	
WP15	Minor impact	+ 100 kCHF
WP17	+ 330 kCHF	+ 62 kCHF

Plus saving in magnet test
(not quantified)

Operational cost + 80 kCHF

Provision in case of need

Total saving CASE A: 575 kCHF
CASE B: 550 kCHF
Total extra-cost CASE A: 425 kCHF
CASE B: 232 kCHF

Net saving CASE A: 150 kCHF
CASE B: 318 kCHF

Case definition

- CASE A:
 - PC installed in the HL UR
 - Connection to the CP via copper cables in the HL UL via vertical cores
 - No solution for cooling of the cable in the cores
 - CASE B:
 - PC installed in the LHC Point 1 and Point 5 bypasses as the present IT PC (LHC ULs)
 - Connection following similar path as the present cables for the DFX
- CASE A':
 - Refined CASE A with solution for the cooling of the cables in the cores



Actions to make feasible the installation of the 120A and 200 A in the UR linking them to the CP with copper cable



- Find solution to provide cooling to the cables installed in the vertical cores
- Optimize PC position to reduce the cable length and reduce integration problems in the UR
- Check that introduced resistance is acceptable for the circuit
- Ensure that the dissipated heat power can be evacuated

Review of the Case A with more details and associated Cost. Here as Case A'


P1@RIGHT

4
racks







Max length of
power cables
≈ 115 -120m





Pc 120 A / 200A








400
x100


SCLINK




UL17








RI171



Moving surface for air leak tightens from UL to LHC tunnel



The proposed solution satisfies EL requirement
Modifying 4 cores (1 each IP Side).

WP17.1

estimated cost

32 kCHF/core

Total

128 kCHF

Images shown here on the left
are purely conceptual and have
been prepared by WP15.
They are not representative of th
possible solution to be proposed
by WP17.1

Remark the flat enlargement at the bottom of the
core would help the installation of the new DFX

WP6B position

- There is no technical showstopper to keep the PCs in the URs. The supplement with respect to the baseline (120 A and 200 A in the sc link) will + 0 CHF for URs vs + 75 KCHF for ULs/USC55 .
- WP6B has communicated the requested minimum cable sections to EL (for 120A and 200A circuits) that respect the power converters limitation of 10V. This takes into account the ramp rate requirements given to us by WP2 and an estimate of the cables length (140 m per polarity). The new increased inductance value of the Quad Corrector (1505 mH vs. 1247 mH before) remains in the margin that has been taken.
-
- The margin taken on the voltage is 20 % and accounts for inductance variation in function of circuit current, possible mutual inductances between circuits, possible inductance evolution from magnet design perspective, etc.
- The indicative cable cross-sections provided by EL to satisfy the WP6B requirements are:
 - **200A : 240 mm²/polarity**
 - **120A : 120 mm²/polarity**

WP 17.2: cabling

- With the previous sections and 120 m the budgeted cable cost is 81 kCHF/IP side
- Total 324 kCHF
- Possible cost increase for installation in the cores

WP17.3: cooling and ventilation

- With the maximum current the following power shall be dissipated
 - Vertical cores: 0.4 kW
 - UL ventilation door to core: 1.9 kW
 - UR: 1.1 kW

2.3 kW UL

- It is needed to install 2 water cooled Fan-Coil in each UL (1+1 redundant). No water drain was foreseen in the ULs.

Small risk in case if water leak: costs

40 kCHF/UL fan coil

10 kCHF/UL collectors (partial compensatory measure)

TOTAL 200 kCHF

The 2 DN20 pipes to feed the Fan-Coil shall be integrated in the same trench with the SC link

Power to be extracted matching full power max current

