A silicon based polarimeter for pEDM searches

James Gooding

E. Vilella-Figueras, G. Casse, N. Rompotis T. Bowcock, J. Vossebeld, J. Price




PSD 2021




Proton EDM


- Overview and experimental method

- Matter/antimatter asymmetry \rightarrow CP violation \rightarrow permanent EDM
- An EDM is caused by separation of permanent charges inside a particle
- Closely connected to spin of the particle which is influenced by E & B fields
- The standard model predicts proton (and neutron) EDM's at the level of 10⁻³¹ e.cm
- Some BSM predict nucleon EDM's in the range 10^{-24} 10^{-28} e.cm range
- Neutron EDM limit: d_n is $(0.0 \pm 1.1) \times 10^{-26}$ e.cm






Current Polarimeter - JePo (JEDI Polarimeter)



www.jara.org/en/research/fame/news/detail/JEDI-Polarimeter-installed

- Protons are sampled from the beam and scattered from a carbon target
- Elastic scattering direction is affected by beam polarization
- LYSO calorimeters are used to determine elastic hits
- Plastic scintillator grid measures positions and thus asymmetry
- Level of L/R asymmetry observed indicates beam polarization




doi.org/10.1088/1748-0221/15/12/p12005

Current Polarimeter


- JePo low energy incompatibility


800µm Steel Beam Window



JePo Angular acceptance 4 – 15 degrees


p-C asymmetry dependence on proton energy





Current Polarimeter


- The necessity of low material budget
 - Strong effect from the current 800 um beam window at lower energies
 - Another approach will be needed for low energy
 - In vacuum, low material polarimeter is desirable




Proposal for a silicon time of flight polarimeter

- Concept and angular acceptance

- HV-CMOS position layer
- LGADs in a time of flight configuration for energy measurement






- Ay is the analysing power (the amount of asymmetry that should be observed for a given polarisation at a given angle)
- Thin detectors can be used with minimal angular resolution loss
 - $4^{\circ} 15^{\circ}$ (Current JePo) $\rightarrow \sim 40^{\circ} 60^{\circ}$ (Low energy polarimeter)
 - Surrounding the detector at a lower rate requires larger detection area.

Not to scale

HVCMOS – High Voltage CMOS

- Overview

- CMOS structure inserted in an isolated deep N-Well
- High resistivity wafers in a standard commercial process allow large depletion to be easily achieved at a low cost compared to other detector systems such as hybrid silicon
- Different available options with active development programme in Liverpool
- Small pixel sizes (50µm×50µm)
- Thin modules (>50µm)
- High radiation tolerance (E15 n_eq/cm^2)
- Time resolution (5ns)
- Power consumption (150 mW/cm^2)




- I. Peric et al (2007)



LGAD – Low Gain Avalanche Diodes

- Overview




Standard n+ implant is typical for silicon diode detectors.

Heavily doped "P" avalanche/gain region producing typical gains of 10-100.

Excellent time resolution in the order of tens of ps.

UFSD2 LGAD


Sensors can be thinned < 300 μ m





http://scipp.ucsc.edu/~schumm/talks/atlas/LGAD/SCHUMM_CPAD-2018.pptx

Low energy polarimeter - Simulation

- Assumed LGAD time resolution 30-50 ps
- A suitable energy resolution of 3% can distinguish between elastically scattered events that can be used for the
- Determine suitable flight length for polarimeter application









Low energy polarimeter


- Simulated Position Resolution


No strict angular resolution is needed (current detector has 1mm resolution)


Position layers help with tracking for energy measurement and give excellent angular resolution regardless














LGAD sensors are USFD2 provided by FBK

Two variations:

- 30 strip, 146 um pitch, 5 mm length
- 20 strip, 216 um pitch, 15 mm length

- Readout

TRB3 TDC module



M Traxler et al 2011 JINST 6 C12004


Extra information: http://jspc29.x-matter.uni-frankfurt.de/trb/publications/201310_NoMeTDC_Ugur.pdf


The third addition to Padiwa-family boards, optimized for direct connection to a MC-PMT - four of these 16 channel boards fit onto the 5x5 cm2 backside of a typical MC-PMT



- Sr90 testing


- Initial testing with a strontium-90 beta source
- Good signals pre-amplified on sensor carrier PCB
- Signals have a good enough SNR for input into PADIWA readout






LGAD Time of Flight telescope


- Sr90 testing



Coincidence results of Sr90 between two layers positioned only 10mm apart.



- Testbeam and particle ID
 - Using spare (out of hours) proton beam time at Rutherford PLC Cancer Treatment centre in Northumberland
 - First testbeam measurements with the LGAD ToF telescope was conducted
 - Results currently being analysed
 - Poor placement for direct proton measurement
 - Telescope observed particles with different time over threshold times possibility that our detectors observed many types of particles and particle identification could be preformed




Beam window

Primary experiment water tank




(off axis)

Thank you for listening! Any Questions?








Backup Slides

Telescope LED/Laser Calibration


Green LED flashes:

- 10 mV signal height
- Rising edge measured can be set to omit oscillation and calibrate time differences between detectors


P 50.00ns/	provention		Measure
	Ŭ		Source
		4	CH1
	1		V Colling and
	A nm		Voltage
and address of the second s	Manager 1	Jan Andrew and -	
	uujuunjun ¥n¥ojo	nije nije na 🖡	Time
			Olaar
			Clear
			1/2
			17 2
PP=10.0mV	Vmax=9.20mU	Umin=-80	




- Split target simulations




- Simulated time resolution







13/09/2021










Telescope control GUI



Easy and precise carriage movement to position sensors


Movement 0




ଷ୍ଟ **ToF Controller** Carridge 1 z 0 Carridge 2 z 0 Carridge 3 z 0 Carridge 4 z 0 🛨 HOME LED Flash Delay 0 LED Flasher Laser Flash Delay 0 Laser Flasher Ŧ ManualControl \rightarrow Var1 0 Var2 0 Var3 0 Var4 0 🛨 COMMAND1 🛨 COMMAND2 🛨 COMMAND3 🛨 COMMAND4 🛨 COMMAND5 Carridge [Carridge] Car1Pos Car2Pos Car3Pos Car4Pos

🛨 CHECKSTATUS

Si3Po




Pellet target feasibility study



Result:

- Pellet target can achieve 2cm offset from main beam whilst retaining stable circulation (100 keV loss in target)





Simulations by Maximilian Vitz


Configuration

A forward configuration will target only one area of figure of merit


- A cylindrical design surrounding the beamline and target will be effective in two areas of high figure of merit.
- Forward area figure of merit strongly influenced by rate, not analyzing power.










Phi measurement accuracy and efficiency





Theta accuracy and efficiency













UNIVERSITY OF LIVERPOOL – JAMES GOODING


Split Target Investigations





1500um thick carbon targets (5mm radius, 15mm spacing)





Carbon (Diamond) 45MeV
















UNIVERSITY OF LIVERPOOL – JAMES GOODING

1° acceptance




Beam defined as 1% larger diameter then pellet:

- 1.97% by definition passes pellet without interaction



39.6 MeV

Figure of merit (cross section x Ay^2)



34

Price/performance	Due to industry standard processes, they are comparatively cheap for the performance when compared to conventional hybrid sensors.
Signal output	Due to in-pixel amplification and processing, the signal output from each pixel is very high and well digitized.
Signal/noise ratio	Low leakage current as well as in pixel amplification causes a high signal-to- noise ratio.
Fill factor (FF)	The readout electronics can be integrated in the sensing area of the pixels which leads to a fill factor close to 100\% although some components such as bias blocks, voltage regulators and I/O pads cannot be built into the sensitive area.
Time resolution	Good timing resolution, up to 5 ns after timing corrections has been achieved.
Radiation tolerance	Large depletion voltages can be used. This leads to fast collection of charge carries from the depleted area which causes the sensors to be less susceptible to radiation damage allowing radiation tolerance of 10 ¹⁵ n _{eq} cm ⁻² .

