

FoCal

Integration into ALICE

Preliminary study



ALICE

26/09/2019

ALICE Technical Board

Corrado Gargiulo



Arturo Tauro

Werner Riegler

Integration into ALICE: preliminary considerations

- FoCal requirements
- ALICE Layout: RUN3 Vs RUN4 (with ITS3+FoCal)
 - FoCal Vs Beampipe
 - Focal Vs Miniframe
 - FoCal Vs ITS, MFT, FIT

FoCal requirements




The HCal consists of lead sheets and scintillator plates.

The mix is 4.55:1 (more lead). The total weight by 1,7m long is about 20Tons.

The ECal is a mix of tungsten and several other materials. An ECal block contains 31kg Wo. The total weight of ECal is about 1.6Tons +0.4Tons for the construction, cooling etc. = about 2Tons.

FoCal requirements



The beam pipe sits between the interaction point and the FoCal and should be **optimised to minimise conversions of photons before they reach FoCal**. Furthermore it is important that the beam pipe has no flanges in the rapidity range for the FoCal; this implies in particular that the main connection should either be placed behind FoCal (at 7.5 to 8.5 m) from the interaction point, or just in front of FoCal ($z=7.0\text{m}$) and have outer radius of 4 cm or less.

ALICE Layout RUN2


ZEM

BLS

BCM

T0

PMD



Compensator
Magnet

Ion pump

BLM


RB24

Anular
Ion pump


Gate Valve

Central beam pipe

ALICE Layout RUN3



Possible ALICE Layout RUN4



Beampipe Instrumentation RUN3 Vs RUN4


BCM & BLM

Functions:


BCM (Beam Condition Monitor) triggers the **Beam Dump** in case of beam losses, and sets the **Injection Inhibit** for the ALICE/LHC injection handshake system.

BLM (Beam Loss Monitor) cross check to BCM from Machine side.

Removal/Displacement implications: their functionality is essential to Machine and ALICE operation. Displacement in Z (upstream Focal) must not affect their functionality, radial position is critical. Removal of BCM is not possible unless the same functionality is restored.



Beampipe layout: RUN3 Vs RUN4




RUN4 layouts of both RB24 and central beampipe will have to be approved by LHC


Beampipe Layout: RUN3 Vs RUN4

central section

Dimension in mm




RUN3



RUN4

Beampipe Layout: central section RUN3 Vs **RUN4**

Gate Valve



Functions: isolate the Beampipe Central section from the adjacent beampipe RB24 section.


At any intervention that requires the disconnection of RB24 the valve is closed avoiding any air contamination of the central section. Gate is closed at Technical Stops for Central BP protection

Removal implications: RB24 disconnection exposes BP central section to air.

The consequence is that the central section will require a new bakeout. This implies the removal of FIT.A, ITS Inner Barrel, ITS Outer Barrel and MFT+FIT_C



Gate Valve



Bellow



Functions: accommodate thermo elastic and mechanical deformation

Removal implications: not possible, change into Aluminum is possible.




Standard Bellow Steel-Copper

Aluminum Bellow




Beampipe Layout: RUN3 Vs RUN4

RB24



RUN4




RB24 Beampipe protection and new Miniframe access procedure (if protection is removed @RUN).

Beampipe Layout: RUN3 Vs RUN4


Dimension in mm

IP=0




FoCal proposal is in conflict with Beam Pipe Vacuum equipment

Beampipe Layout: RUN3 Vs RUN4




Beampipe Layout: central section RUN3 Vs **RUN4**





ION PUMP

Functions: It pumps non-gatherable gases (CH₄)
It is a standard LHC ion pump: Pumping speed for CH₄ $\approx 30 \text{ l.s}^{-1}$ (at $1\text{e-}10 \text{ mbar}$).
Located at about 9m from IP




Removal/Displacement implications:
functionality is essential to Machine and ALICE operation. Cannot be removed. Upstream displacement could affect vacuum quality. It would require deep study.

FoCal pseudorapidity and beampipe RUN3 Vs **RUN4**




Beampipe supports: RUN3 Vs RUN4

RUN3





RUN4



Supports must be on FoCal Platform



Supports must be on the TPC



269 cm

244 cm

LIMITED ROOM
IN THE MINIFRAME






Largeur recommandée (en mètres)

Largeur d'un passage habituel entre machines ou éléments d'installation	0.8 (distance réglementaire)
Largeur d'un accès pour intervention occasionnelle (dépannage, maintenance)	0.6 (1)

(Note 1) 0,8 si aces en cul-de-sac sur plus de 3 metres



LIMITED ROOM IN THE MINIFRAME


RESTRICTION OF SIDE PASSAGE
FoCal SERVICES VOLUME?



INSTALL-REMOVE

2 HALVES TO AVOID BP DISMOUNTING
LIMITED CRANE ACCEESS






SUPPORT

FEASIBILITY STUDY INCLUDING SEISMIC ANALYSIS
REQUIRED
MAGNETIC FIELD PROXIMITY AFFECTS MATERIAL CHOICE

SUPPORT

L3 VENTILATION DUCT ON THE WAY OF THE SUPPORT





FoCal Vs FIT.A

CONICAL BP MINIMUM GAP WITH FIT.A

* Does not include permanent bakeout (+10mm/Diam)

YETS (13 weeks)

Remove Shielding PX+ (UX)
Remove FoCal
Open FIT.A
Remove BCM/BLM, BP protection
Remove ITS-IB
Remove ITS-OB
Remove MFT+FIT.C
Install MFT+FIT.C
Install ITS-OB
Install ITS-IB
Install BCM/BLM BP protection
Close FIT.A
Install FoCal
Install Shielding PX+ (UX)

FoCal Vs ITS, MFT-FIT.C

THE ITS+MFT+FIT.C REQUIRES FoCal REMOVAL

[Click for movie](#)

Summary

Focal installation in ALICE implies:

- New Central Beampipe, new RB24 Beampipe
- RB24 Beampipe protection and new Miniframe access procedure (if protection is removed @RUN).
- Removal of Gate Valve → exposes BP to air at any disconnection of BP sections on the MNF →bakeout
- Removal of Focal/FIT/ITS/MFT for bakeout
- Reduction of Focal length (displacement) to preserve Ion pump position
- BLM and BCM functionality to be preserved
- Impact on ITS, MFT-FIT.C access time → FoCal must be removable w/o BP disconnection→2 halves
- Need to ensure/verify that the servicing of ITS/MFT can indeed be performed during a 13 week winter stop
- Reduction of clearance between Beampipe and FIT.A
- Removal of ZEM
- Access limitation on Miniframe →FoCal overall envelope and services TBD
- New Platform-Support (23 ton)→feasibility study → non magnetic material and seismic analysis
- Special handling procedure→crane limit due to L3 door proximity
- Modification of L3 air duct, new Beampipe supports, ...