



# MBHA-001 test program discussion

G. Willering

G. Ninet

F. Mangiarotti

V. Desbiolles

M. Bajko

Magnet test program in report EDMS [2268372](#)



**2019 November 13 – 11T technical meeting**

# Contents

## **Comparing test program for MBHA to MBHB.**

- Cool down and warm up conditions
- HV tests
- Training/holding current tests
- QPS settings
- 4.5 K test
- Magnetic measurements
- Cyclic loading tests
- RRR

## **Main difference MBHA compared to MBHB**


- Presence of 250 A trim circuit.
- Presence of 550 A MCS circuit and 100 A MCO circuit.

## **Planning**




# Cool down and warm up

- MBHB-002:  $\Delta T$  of 30 K (abort process at  $>45$  K)
- MBHB-002:  $\Delta T$  of 30 K (abort process at  $>45$  K)



# Overview low current powering up to 6 kA



Done in MBHB-002

Same proposed for MBHA-001 Cool Down 1





Cool down 2:

Skip low current splice and 6 kA QI.

# Flux jumps and Quench Detection settings


Protection settings optimized for flux jump in MBHB.  
 Table below shows the settings as used in CD 2.  
 Proposed for MBHA-001 are the same settings.

| Current range                       | Threshold, validation time |   |
|-------------------------------------|----------------------------|---|
|                                     | Lowest treshold            | Shortest validation time                    |
| $I < 1.5 \text{ kA}$                | 150 mV, 300 ms             | 900 mV, 50 ms (insufficient for protection) |
| $1.5 \text{ kA} < I < 6 \text{ kA}$ | 200 mV, 50 ms              | 400 mV, 10 ms (insufficient for protection) |
| $6 \text{ kA} < I < 9 \text{ kA}$   | 100 mV, 10 ms              | 150 mV, 8 ms                                |
| $9 \text{ kA} < I$                  | 100 mV, 5 ms               | 150 mV, 3 ms                                |




Threshold at 1.5 kA (200 mV, 50 ms) seems to have least margin to flux jump duration. (can we predict flux jump for MBHA?)

# Overview high current powering > 6 kA




Proposed for MBHA-001

Magnetic measurements (2 days)



Additional done in MBHB-002


330 cycles from 5 to 11.85 kA in CD 2  
(12 hours continuous cycling)



# Magnet training

Training up to 11.95 kA maximum (see EDMS 2213035).  
Ramp rate 10 A/s.

MBHB-002 training was very fast with 2 quenches. Hopefully similar for MBHA-001, although more quenches are not excluded.



# Stable current

## Done for MBHB-002

### Cool down 1:

1.9 K, 11.85 kA, 2 hours

4.5 K, 11.85 kA, 1.5 hours

### Cool down 2

1.9 K, 11.85 kA, 12 hours

1.9 to 4.5 K, 11.85 kA, 3 hours

## Proposed for MBHA-001

### Cool down 1:

1.9 K, 11.85 kA, 12 hours

1.9 to 4.5 K, 11.85 kA, 3 hours

### Cool down 2

1.9 K, 11.85 kA, 4 hours

1.9 to 4.5 K, 11.85 kA, 3 hours




# Ramp rate studies


MBHB-002: Ramp up: up to 100 A/s performed.  
Ramp down: up to -125 A/s in the SPA test. *(required for the LHC during RB energy extraction).*

MBHA-001: One relatively fast ramp at 50 A/s foreseen at 1.9 K, followed by SPA of - 125 A/s to show this gives no false trips.

*Any ramp at 4.5 K will likely not be feasible due to flux jumps in combination with protection levels.*



# Magnet margin at 4.5 K



Done for MBHB-002: Drifting from 1.9 K to 4.5 K while powering. This avoids flux jump trips at low current.

Proposed for MBHA-001: Same method is proposed (excluding high current cycling).


Total time about 5 hours (20 min ramp up, 2 hour T-drift, 1 hour flattop, 1 hour back to 1.9 K).

# Splices

## MBHB-002

| Splice    | Resistance [nΩ]  | Comment               |
|-----------|------------------|-----------------------|
| 1213-1214 | 0.15 (1 splice)  | NbTi-Nb3Sn            |
| 1221-1224 | 0.54 (3 splices) | Nb3Sn-NbTi-NbTi-Nb3Sn |
| 1231-2231 | 0.61 (3 splices) | Nb3Sn-NbTi-NbTi-Nb3Sn |
| 2244-2241 | 0.50 (3 splices) | Nb3Sn-NbTi-NbTi-Nb3Sn |
| 2254-2253 | 0.13 (1 splices) | NbTi-Nb3Sn            |


Done in MBHB-002: measure up to 3 splices combined. Only if resistance is high  $> 1$  nOhm per 3 splices, redo measurements for individual splices.



Proposed for MBHA-001: Same method.

# RRR

Done in MBHB-002: Accurate transition resistance measurement with slow drift of magnet temperature.



MBHA-001: Two options:

1. Use same method during first warmup (Could waste precious time, half a day minimum, but also impossible if just before a weekend).
2. Find a better moment (*During cooling after a quench, abort cooling once full coil is superconducting, wait until magnet warms up to full transition, then restart cooling down. Other option is after 4.5 K test.*)




For now option 1 is in the test program. If we manage option 2, option 1 will be discarded.

**Seen as important parameter.**  
**Most important: avoid time loss.**

# Quench integral study at 6 kA and 11.85 kA

Quench heater firing at nominal current gives multiple important data:

- Voltage imbalance between coils following heater firing (important in HV calculations)
- Quench Integral
- $di/dt$  characteristics.
- Quench Heater efficiency



MBHB 1.9 K, 11.85 kA

Total resistive voltage = 6500 V.  
Voltage Aperture 1: 3040 V  
Voltage Aperture 2: 3460 V  
Imbalance of 14 %

Heater firing at nominal current, without a natural quench in the magnet.  
420 V resistive voltage imbalance between aperture 1 and aperture 2

# High Voltage insulation test, instrumentation tests

MBHB-002 and MBHA-001 tests identical.

Note:

MBHB-002 has an MCS magnet circuit.

MBHA-001 has an MCO and MCD magnet circuit.

MBHA-001 has **trim leads**, which are connected to the main circuit. By definition it will see the potential of the main circuit.

| Polarity +             | Polarity -              | Warm initial | cold              | Warm final |
|------------------------|-------------------------|--------------|-------------------|------------|
| Dipole-Quench Heaters  | Ground                  | 300/660      | 300/660/1850/3300 | 300/660    |
| Dipole                 | Quench Heaters - Ground | 300/660      | 300/640/1850/3200 | 300/660    |
| Dipole                 | Ground                  | 300/660      | 300/660/1850/3300 | 300/660    |
| Dipole                 | All Quench Heaters      | 300/660      | 300/640/1850/3200 | 300/660    |
| All Quench Heaters     | Ground                  | 300/660      | 300/660/1850/3300 | 300/660    |
| Dipole                 | MCS-MCD Correctors      | 250          | 250/975           | 250        |
| MCO/MCD Correctors     | Ground                  | 250          | 250/975           | 250        |
| Ext/Int Passive Busbar | Ground                  | 600          | 600/1850/3075     | 600        |
| Ext Passive Busbar     | Internal Passive Busbar | 600          | 600/1850/3075     | 600        |
| Cryo Heater            | Ground                  |              | 675               |            |
| Cold Temp. Sensor      | Ground                  |              | 25                |            |
| Dipole                 | QH1 to QH 8             | 300/660      | 300/640/1850/3300 | 300/660    |
| QH1 to QH 8            | Ground                  | 300/660      | 300/660/1850/3300 | 300/660    |
| Dipole                 | Lead EF_BB11&12         | 250          | 250/975           | 250        |
| Lead EF_BB11&12        | Ground                  | 250          | 250/975           | 250        |

Test request: 200 K, 3 bar, 750 V during final warm up.  
Risk and impact on planning not know yet.  
Manual operation, not easy.

# Magnetic Measurements

MBHB: Full measurement set done by Lucio, see EDMS [2219199](#)


MBHA: **No time allocated to MM, low priority.**

The MM shaft will be used already for quench localisation.

If time permits a machine cycle may be possible.


# Trim leads

300 K




Developed length of conductors: 1404 mm

2 temperature probes glued on copper block.



20 K?





Thermalization


Helium gas flow from CFB boiloff, through magnet feet, then through thermalisation, returning through screen.  
Helium T measurement only at exit.  
No helium flow measurement.




Voltage across 11T trim leads @20 K 3.3 g/s



Cold powering test of 11T trim leads @ 20 K, 3.3 g/s




Cold powering test of 11T trim leads @ 20 K, 3.3 g/s



1.5 hour stabilisation time

# Trim leads


- Powering with 600 A PC. 13 kA PC always disconnected.
- Quick resistance measurement on 2 minute plateaus, no stabilisation.
- Protection:
  - Normal conducting parts: 150 mV, 10 ms
  - SC parts: 50 mV, 10 ms
- Most important test stable conditions at 250 A.
  - In case of failure, repeat at 220 A.



No time or technical possibility for playing with helium flows and temperatures.

# Planning

- Zero contingency in planning, including extended working hours for preparation and test.
- Target is start of warm up



MBHAR-01, 11 T series