



Investigation of  
**mechanical degradation mechanism**  
onto the quench heater insulation to Nb<sub>3</sub>Sn coil


TE-MS-C-LMF

Felix Wolf, Arnaud Foussat and Jan Petrik

11.12.2019

# Content

- Study of **failure mechanism** of the insulation system between quench heater and cable under **compressive load** Samples
  - The samples
  - Test machine
  - Measurement results



*Quench heater of the 11T dipole magnet, placed in the show box in front of the winding hall in bldg. 180.*

# Investigation of mechanical degradation mechanism onto the quench heater insulation to Nb<sub>3</sub>Sn coil


Introduction

## Findings on MBHP001 - CR06-07

- Direct shorts provoked in collared coil state was found in same cross sections on paired coils, residual resistance of few Ohms.



Short after successive C bank discharges in CR06



Short detail after peeling test





Type of direct short defect created in extended Hi-pot test on CR07, ( hole diam 2 mm, dumped E tot > 1kJ)

## Objective of the study:

Study of failure mechanism of the insulation system between quench heater and cable under **compressive load**.

# Investigation of mechanical degradation mechanism onto the quench heater insulation to Nb<sub>3</sub>Sn coil Compressive load



## Objective:

- Study of **failure mechanism** of the insulation system between quench heater and cable under **compressive load**

## Test:

- Compressive test + online leakage current measurement

## Sample:

- 11T Nb<sub>3</sub>Sn Rutherford cable (H150 C02 244A)
- Mica insulation + fibre glass braiding (identical to coil 108)
- 18-stack with cancelling keystone angle
- Impregnated quench heater (11T Non-Conform 1st Trackwise piece 08.03.2018)

## Test machine:

- 180 kN hydraulic press, equipped with calibrated load cells Burster type 8526 (0-200kN)
- Steel press tool, insulated with multilayer 0.125mm polyimide film
- Electrical measurement device (Keithley 6487 pico amper meter)

# Investigation of mechanical degradation mechanism onto the quench heater insulation to Nb<sub>3</sub>Sn coil

Status of sample preparation for compressive load scenario

Ceramic binder curing

- Cycle 80°C (1h), 150°C (2h)

Reaction heat treatment


- Cycle 20°C/h to 650°C (20h) (Bldg. 927)

Impregnation

- New mould to apply radial and transversal compression
- Vacuum impregnation with CTD-101K


Samples with varying insulation thickness (S2-glass fibre)

- 250 µm (2 samples)
- 250-200 µm (2 samples)
- 200 µm (3 samples)
- <150 µm (3 samples)




Contact area of the cable

Pressure sensitive film FUJI-LW indicating a pressure range between 2.5-10 MPa during a test assembly.




RHT mould enabling clearance variation for up to 18 cables, enables ceramic binder application





Prepared sample in the impregnation mould which enables radial and transversal compression

# Investigation of mechanical degradation mechanism onto the quench heater insulation to Nb<sub>3</sub>Sn coil


Test equipment



\* Maximum Continuous Input: 505V Peak.



Sample with electrical connections installed in the press gap



Hydraulic press ( $F_{max.}=180$  kN)

Keithley 2001

Keithley 6487


DAQ

Test machine with measurement equipment


# Investigation of mechanical degradation mechanism onto the quench heater insulation to Nb<sub>3</sub>Sn coil

Microscopic analysis of the insulation thickness


- Samples prepared with varying insulation thickness adjusted by impregnation mould clearance
- Insulation thickness determined by microscopy (**fibre glass + polyimide**)
- Contact pressure determined with LW Prescale film



150µm insulation CR06  
250µm insulation QHC02  
Contact pressure <2.5 MPa (local)




150µm insulation CR06  
200µm insulation QHC05  
Contact pressure >2.5 <10 MPa (local)




150µm insulation CR06  
150µm insulation QHC10  
Contact pressure >2.5 <10 MPa (local)

# Investigation of mechanical degradation mechanism onto the quench heater insulation to Nb<sub>3</sub>Sn coil

Leakage current measurement **without applied pressure**



Leakage current measurement at **500V without load** of sample QHC12 (<150 $\mu$ m), determined resistance about 3.5 T $\Omega$ .




Leakage current measurement at **500V without load** of sample MQXF\_QHC01 (<150 $\mu$ m).

- Good repeatability of the leakage current measurements at stable ambient conditions
- Leakage current decreases towards an plateau value
- Leakage current is very sensitive to:
  - Ambient conditions
  - Time gap between measurements



# Investigation of mechanical degradation mechanism onto the quench heater insulation to Nb<sub>3</sub>Sn coil


Leakage current measurement **with applied pressure**




- Leakage current plateau after 25 minutes
- No change in the leakage current if the load ramp is below 0.1 kN/s
- No permanent degradation of the insulation up to 60 MPa
- Reversible changes of the resistance if the load ramp is above 0.5 kN/s

*Leakage current measurement at 500V with varying load and varying load ramp rate of sample QHC07 (<150 $\mu$ m), determined resistance about 1.5 T $\Omega$ .*

# Sample QHC07 (Insulation thickness < 150 $\mu$ m) loaded up to 110MPa




Leakage current measurement at 500V with load ramp rate 0.13MPa/s QHC07 (<150 $\mu$ m insulation thickness).




- No permanent degradation of the insulation up to 60 MPa
- Leakage current increases before the sample loses mechanical strength
- Leakage current increases above an applied load of 90 MPa
- Sample loses mechanical strength and delaminates

## Sample QHC10 (Insulation thickness < 150 $\mu$ m)




Leakage current measurement **at 500V** with load ramp rate 0.13MPa/s QHC07 (<150 $\mu$ m insulation thickness).



Leakage current measurement **at 500V without load** of sample QHC10 (<150 $\mu$ m), determined resistance about 5 T $\Omega$ .

- Sample prepared with higher compression (extra 100 $\mu$ m polyimide shim).
- Leakage current increases with at load above 60 MPa.
- Time dependent leakage current increase, even at decreased load.
- Clear change of the leakage current behaviour without applied load after 80MPa loading.

## Thermal cycle of one sample to 1.9K



Shaft of the sample holder from the cryostat

Sample attached on the sample holder




*Sample installed at the sample holder of the cryostat in Bldg. 163 for cool down to 1.9K.*

*Cracks in the insulation system (bottom surface of the sample) after cool down to 1.9 K.*

- Cryogenic cool down in a cryostat with liquid helium to 1.9 K
- cooling rate of about 75 K/h
- warm up rate about 100 - 150 K/h


# Leakage current measurement after thermal cycle to 1.9K without load



*Leakage current measurement at 500V without load.*




- No effect on the leakage current after sample drying
- Absolute value is influenced by the ambient conditions

# Leakage current measurement after thermal cycle to 1.9K under applied load



- No effect on the leakage current under applied load up to 60 MPa

## Dye ink penetration test with the cryogenic cooled samples



*Dye ink penetration test of the sample after cool down to 1.9K*

## Dye ink penetration test with the cryogenic cooled samples



*Sample with peeled off quench heater after cryogenic cycle to 1.9 K.*



# Overview of the 11T type samples



Sample ID	Insulation thickness [µm]	Status	Tests	HV test 3.2 kV for 120s	HV test 3.2 kV for 120s
HC01	~250	Ok	7.3 kV@ 0 MPa, 5.2kV@ 80MPa, 4.1kV @ 0MPa	Passed	
HC02	~250	Cut – Microscopy	4.9 kV @ 0 MPa, 5.5kV@ 80 MPa –cut	Passed	
HC03	~200	Ok	Tested up to 60 MPa	Passed	
HC04	200-250	Ok	Tested up to 60 MPa	Passed	
HC05	~200	Cut- Microscopy	Cut	Not tested	
HC06	200-250	Ok	Tested up to 60 MPa	Passed	
HC07	<150	Destroyed	Failed at 110 MPa	Not tested	
HC08	~200	Peeled after 1.9K	Tested up to 60 MPa	Not tested	
HC09	<150	Destroyed	Failed at 90 MPa	Not tested	
HC10	<150	Cut for Microscopy	Tested up to 80 MPa	Not tested	
HC11	<150	Ok	Without glass fibre / mica, Tested up to 60 MPa	Passed	
HC12	<150	Pending repair	Spare sample (defect after demoulding)	Failed at 2.67kV	
HC13	<150	Ok	Spare sample	Passed	After 1.9K passed



# Outlook on 11T samples


**Objective:** Reproduce and determine the failure mechanism in the insulation system after thermal cycle

- Manufacture samples with defects in the impregnation system
  - Realized by a vacuum during the sample curing
- Manufacture samples where the heaters can be fired
- Perform the test in the collaring mock up with coil segments
  - To be discussed
- Update the test station for leakage current investigations at 3.7kV
  - Work in progress



# Outlook on 11T samples

- Can we fire the heater?
  - Not designed/manufactured for this approach




*Stainless steel part the quench heater in the samples placed at the edge of the cable stack.*

# The MQXF samples


- Investigation of the MQXF insulation system without mica

- Target insulation thickness (205 $\mu$ m)

- 145 $\mu$ m S2 glass + 50 $\mu$ m QH polyimide



Pressure on sample MQXF\_01 applied by the impregnation mould during a test assembly, visualized by pressure sensitive film FUJI LW indicating a pressure range between 2.5-10 MPa.



*Simplified model of the impregnated MQXF sample with quench heater, soldered electrical connections and residual epoxy block*




*Impregnation mould for the investigation of the MQXF impregnation system.*



*Impregnated MQXF sample.*

# The MQXF samples


MQXF sample overview



Cross section of sample MQXF-QHC-03 with insulation thickness of 150 µm (glass fibre).

Sample ID	Expected S2 insulation th. [µm]	Tests	HV test 3.7 kV for 120 sec.	1.9K HV test 3.7 kV for 120 sec. Ramp 1kV/min
MQXF_01	150 µm	Tested up to 60 MPa	Passed	Break down 1. 2026 V 2. 1608 V 3. 1533 V 4. 1536 V 5. 1600 V
MQXF_02	150 µm	Tested up to 60 MPa	Passed	
MQXF_03	150 µm	Tested and cut	Not tested	
MQXF_04	150 µm	Tested up to 60 MPa	Passed	
MQXF_05	150 µm	Tested up to 60 MPa	Passed	
MQXF_06	150 µm	Tested up to 60 MPa	Passed	


## Leakage current measurement without load (MQXF samples)



*Leakage current measurement of the sample MQXF-QHC04 without applied load at 500 V DC.*

- Good repeatability at stable ambient conditions


## Leakage current measurement loaded up to 60 MPa (MQXF samples)




*Leakage current measurement under radial applied load over time of sample MQXF-QHC04 at 500V DC test voltage.*

- No permanent impact on the leakage current due to applied load.




# High voltage test after cool down (1.9K) MQXF\_01



Leakage current activity can be observed before the break down.



Break down location on the MQXF-01.





**Thank you for your  
attention.**