The first piece of the MACS procedure framework (ProShell)

Angela Brett

A framework which can run prodedures that perform operations on devices and sets of devices (working sets.)

A procedure is a C# class implementing a certain interface, which will be loaded dynamically from a file.

The procedure framework will communicate with devices using PVSS

PVSS

PVSS is a SCADA (Supervisory Control and Data Acquisition) system. It can be used to connect to hardware devices to control them and acquire data from them.

PVSS has a scripting language and a graphical user interface, but a procedure framework implemented using these would run too slowly.

The PVSS API allows users to write their own programs in C++ which can access the data and control the hardware devices via PVSS datapoints.

How do we bridge this gap?

SWIG

SWIG

SWIG (Simplified Wrapper and Interface Generator) is free software that can create wrappers that allow C or C++ APIs to be used from other languages.

I used SWIG to create a wrapper for the PVSS API. It took about a month to fine tune the wrapper and write prototype code to ensure that all the features of the PVSS API could be used.

PVSSProxy

SWIG

PVSSProxy is a library which allows easy use of the SWIG wrapper without knowledge of the underlying API.

All of the main functionality of PVSS is made available using common C# patterns:

- Asynchronous calls use C# delegates.
- Datapoints values can be set and retrieved using native C# data types.
- Errors are raised as exceptions.
- PVSSProxy manages the PVSS event loop, so client code only needs to call one method to connect to PVSS.

PVSSProxy should also make some things easier to code than they would be in a PVSS script.

DatapointName class simplifies the use of datapoints. Instead of remembering how to make a full datapoint name string such as:

Datapoint.element:_config.Detail._attribute

You create a DatapointName object with only the essential properties, and the rest can be filled in automatically depending on what you are doing.

DatapointName will also allow wildcards to get names and values of many datapoint elements at once.

To do:

- Add more source code documentation
- Add the ability to disconnect from PVSS
- Make timeouts configurable
- Add logging using log4net
- Allow wildcards in datapoint names
- Add more unit testing
- ...and implement the procedure framework.

PVSSProxy

SWIG