

Overview of Providers

Workshop on LHC Post Mortem
Session 4 - Data Providers, Volume, Type of Analysis

Robin Lauckner

Abstract

Post Mortem will be the key to mastering the full complexity of LHC Operation and the interaction between systems. Many systems will be involved in full optimisation and understanding of performance. Today a few systems are providing data to validate and understand hardware commissioning. This must be extended giving priority to obtaining essential information related to achieving first collisions. This talk will review systems involved, discuss the nature of the information to be provided and attempt to identify some priorities. The vacuum system will be examined to demonstrate how these demands are being met.

This Session

Key Words:

- Data Providers
- Volume of Data
- Type of Analysis

Talks:

- Overview of Providers - Robin Lauckner
- RF - Andy Butterworth
- BI - Stephane Bart Pedersen
- Kickers - Etienne Carlier
- Collimators - Michel Jonker

What Data Is Required to Understand 'Failures' During LHC Operation?

Check list of LHC systems that should record data for Post Mortem. Those already pushing data indicated "YES"

Client	Alarms	Logging	Transients	Client	Alarms	Logging	Transients
Access System				Energy Extraction ●			YES
Alice Interlocks				Inflector			
Atlas Interlocks				LHCb Interlocks			
Beam Current Monitors				Power Converters ●	YES	YES	YES
Beam Dump				Powering Interlocks ●	YES	YES	
Beam Interlocks				Quench Protection ●			YES
Beam Feedback Systems				QRL Instrumentation		YES	
Beam Loss Monitors				Radiation Monitors			
Beam Position Monitors				Reference Magnets			
Beam Profile Monitors				RF System			
CMS Interlocks				Timing System			
Collimators				Transverse Dampers			
Cooling and Ventilation		YES		Tune and Aperture kickers			
Cryogenics, production ●		YES		Vacuum ●		YES	
Cryostat Instrumentation ●				Warm Interlocks			
Electricity Distribution		YES					

Priority Suppliers for Cold Powering ●

- QPS
- Energy Extraction
- Powering Interlocks
- Cryogenics
- Vacuum
- Power Converters

Many systems already publishing in the injectors

How much transient data during circuit commissioning?

Suppliers are QPS, PC and PIC

During Powering to Nominal circuits will generate PM data during tests

- Energy Extraction Discharge
- Powering Failure
- Fast Power Abort from PIC
- Heater Firing
- Artificial Quench
- Loss of sub-converter

Assume each converter generates 1.3 MB, QPS 1MB during a test. The PIC volumes are much smaller, a full powering sub-sector abort writes 6.4 kB on to logging.

Further assume that during heater firing tests 2 magnets of a 13 kA circuit are tested and each aperture of the MQM type circuits?

This gives about 4000 tests yielding some 11 GB of data on the PM server.

PIC1 and PIC2 tests expected to yield a similar amount

Circuit Commissioning Transient Data Estimate

	Tests	Cirs	PC	QPS	Sums
			MB	MB	MB
13 kA Main	17	24	1.3	1	938
IP Q&D	15	94	2.6	1	5076
600A EE	7	202	1.3	1	3252
600A no EE CR	5	136	1.3	1	1564
600A no EE	4	8	1.3	1	74
80-120 A					
60A					
Totals	48	464			10904

	P C S	PLI1						PLI2						PLI3				PLI4		PNO						P S Q	P A C	
		1	2	3	4	5	6	7	1	2	3	4	5	6	1	2	3	4	1	2	1	2	3	4	5			6
13 kA Main			1	1	1	2				1	1	2	1				1	2		1			1	2				
IP Q&D				2	1	2				2		2	1					2					1	2				
RTQX2																												
RTQX1																												
IT RTQXA																												
RTQXM																												
RQX																												
600A EE			1	1	1					1	1						1						1					
600A no EE CR				1	1		1			1													1					
600A no EE				1	1		1																1					
80-120 A																												
60A																												

Priority Suppliers for Beam Run

- Beam Dump
- Powering data
- Beam Loss
- Beam Position
- RF

How much data during beam commissioning?


A full LHC Post Mortem will give several GBs data (PC = 2, BL = 2, RF = 2)

Expect (hopefully?) 100 GB / week early on – more tricky!


Types of Analysis

- Generic Analysis
- External Analysis
- Specific Analysis

Rüdiger plot - Different systems and sources




Developed for LHC h/w



Existing investment of AP s/w



Hardware configuration for the Vacuum system



Slide from Isabelle Laugier

Logging of Vacuum Data

- Logging into PVSS
 - Change of state of Sector valves, with UTC time from PLC
 - Value of the pressure for Gauges and Pumps with UTC time from PLC.
- Logging into LHC logging DB from PVSS(not active for the moment but ready)
 - Value of the pressure for gauges and pumps with UTC time from PLC.
- To be added today:
 - Logging of change of state of sector valves,

Slide from Isabelle Laugier

Sector valve change of status in PVSS for SPS

State_History

Interval Selection

From: 15-Oct-06 17:15:46 To: 16-Jan-07 17:15:46 Show

Time	WSA_10101
2006.11.09 21:30:56.792	Open
2006.11.09 21:31:03.792	Open
2006.11.14 23:40:53.785	Undefined
2006.11.14 23:41:00.753	Closed
2006.11.14 23:43:25.779	Closed
2006.11.14 23:44:21.777	Open
2006.11.15 01:47:54.789	Closed
2006.11.15 01:48:53.771	Closed
2006.11.15 01:51:48.795	Open
2006.11.15 05:37:36.791	Closed
2006.11.15 05:38:44.773	Open

Close Help

Slide from Isabelle Laugier